

**DIVISION6.GR6**      **Structures**

**6-01.GR6**              **General Requirements For Structures**

**6-01.5.GR6**              **Work Access and Temporary Structures**

**6-01.5.INST1.GR6**      (Section 6-01.5 is re-titled and revised to read:)  
Must use once preceding any of the following:

**6-01.5.OPT1.FB6**      (Work Access)  
(April 1, 2019)  
Use in projects requiring the Contractor to construct work access to perform structure removal and construction, including work trestle construction for work within or above an environmentally sensitive area as required by resource agency environmental permits and restrictions. The fill-in specifies the name of the environmentally sensitive area or waterway. Include with **6-01.5.OPT1(B).GB6**.  
Must use once preceding any of the following:  
(1 fill-in)

**6-01.5.OPT1(A).FB6**      (Waterway Clearance Requirements)  
(April 6, 2015)  
Use in projects requiring the Contractor to construct the work access structure to conform to navigation clearance requirements of the USCG. The first fill-in specifies the minimum horizontal clearance required for the channel span. The second fill-in specifies the minimum elevation required for the bottom of the work access structure superstructure. Include with **6-01.5.OPT1.FB6** and **6-01.5.OPT1(B).GB6**.  
(2 fill-ins)

**6-01.5.OPT1(B).GB6**      (Payment)  
(April 6, 2015)  
Use in projects requiring the Contractor to construct work access to perform structure removal and construction, including work trestle construction for work within or above an environmentally sensitive area as required by resource agency environmental permits and restrictions. Include with **6-01.5.OPT1.FB6**.

**6-01.5.OPT2.FB6**      (Temporary Bridge)  
(August 6, 2018)  
Use in projects requiring construction of a temporary bridge. The first fill-in specifies the minimum overall length of the temporary bridge, and can also be used to specify requirements for number of spans and lengths of specific spans, if necessary. The second fill-in specifies the minimum roadway width required between barriers or railings. The third fill-in specifies the minimum vertical clearance dimension to the roadway, body of water, or surface, specified in the fourth fill-in. If the length, width or

vertical clearance of the temporary bridge is shown in the plans, the specific geometric requirement item text in the specification can be deleted (or if all are shown in the plans, the entire geometric requirements paragraph can be deleted).

(4 fill-ins)

## **6-02.GR6**

### **Concrete Structures**

## **6-02.2.GR6**

### **Materials**

#### **6-02.2.INST1.GR6**

(Section 6-02.2 is supplemented with the following)  
Must use once preceding any of the following:

#### **6-02.2.OPT2.GB6**

(Epoxy Bonding Agent For Surfaces And For Steel Reinforcing Bar Dowels)  
(September 8, 2020)

Use in projects when epoxy resin is required for setting steel reinforcing bars into holes drilled into concrete. Include with **6-02.3(24)C.OPT1.GB6**.

#### **6-02.2.OPT4.GB6**

(Epoxy Crack Sealing)  
(November 2, 2022)

Use in projects which require sealing cracks in existing concrete with injected epoxy resin. Include with **6-02.3.OPT1.GB6** and **6-02.5.OPT49.GB6**.

#### **6-02.2.OPT26.GB6**

(Rapid Cure Silicone Sealant)  
(April 6, 2015)

Use in projects where rapid cure silicone sealant is used for expansion joint modification. Include with **6-02.3(13).OPT7(C).GB6**, either **6-02.3(13).OPT7(I).GB6** or **6-02.3(13).OPT7(J).GB6**, **6-02.4.OPT8.FB6** and **6-02.5.OPT33.GB6**, and all other applicable expansion joint modification GSPs supplementing Sections 6-02.2 and 6-02.3(13).

#### **6-02.2.OPT27.GB6**

(Polyester Concrete)  
(April 6, 2015)

Use in projects where polyester concrete is required. Include with **6-02.3.OPT9.GB6**.

#### **6-02.2.OPT28.GB6**

(Elastomeric Concrete)  
(April 6, 2015)

Use in projects where elastomeric concrete is required. Include with **6-02.3.OPT10.GB6**.

#### **6-02.2.OPT46.GB6**

(Bridge Supported Utilities)

Must use once preceding any of the following:

#### **6-02.2.OPT46(A).GB6**

(June 26, 2000)

Use in projects with bridge supported utilities when the supports include concrete inserts. Include with **6-**

**02.3.OPT2(A).GB6, 6-02.4.OPT1.FB6, and 6-02.5.OPT26.FB6.**

6-02.2.OPT46(B).GB6 (Bridge Supported Utilities)  
(September 3, 2019)  
Use in projects with bridge supported utilities when the supports include steel rods, bars, and plates. Include with **6-02.2.OPT46(A).GB6, 6-02.3.OPT2(A).GB6, and 6-02.5.OPT92.FB6**, and either **6-02.3.OPT2(B).GB6**, or **6-02.3.OPT2(C).GB6** and **6-02.5.OPT93.GB6**.

6-02.2.OPT46(C).GB6 (Bridge Supported Utilities)  
(September 3, 2019)  
Use in projects with bridge supported utilities when the supports include transverse braces. Include with **6-02.2.OPT46(A).GB6, 6-02.2.OPT46(B).GB6, 6-02.3.OPT2(A).GB6**, and **6-02.5.OPT92.FB6**, and either **6-02.3.OPT2(B).GB6**, or **6-02.3.OPT2(C).GB6** and **6-02.5.OPT93.GB6**.

6-02.2.OPT46(D).GB6 (Bridge Supported Utilities)  
(June 26, 2000)  
Use in projects with bridge supported utilities when the supports include pipe rolls or pipe saddles. Include with **6-02.5.OPT92.FB6** and other applicable bridge supported utility material and construction requirement GSP's.

6-02.2.OPT46(E).GB6 (Bridge Supported Utilities)  
(September 3, 2019)  
Use in projects with bridge supported utilities in concrete box girder bridges when the utilities are supported on anchor blocks on the bottom slab. Include with **6-02.5.OPT92.FB6** and other applicable bridge supported utility material and construction requirement GSP's.

6-02.2.OPT48.GB6 (Bridge Drain Risers)  
(April 30, 2001)  
Use in projects requiring the raising of bridge drains prior to asphalt or modified concrete overlay work on bridge decks. Include with **6-02.3(10)D.OPT3.GB6**. Also include with **6-02.3(10)D.OPT4.GB6** if the bridge deck is overlaid with membrane waterproofing and ACP. Include with **6-02.5.OPT53.FB6** if the work is included in the cost of the membrane waterproofing or modified concrete overlay. Include with **6-02.4.OPT26.GB6** and **6-02.5.OPT51.GB6** if the unit contract bid item "Modify Bridge Drain" is used to pay for the work.

6-02.2.OPT58.GB6 (Core Drilled Bridge Deck Drain)  
(September 8, 2020)

Use in projects with core drilled bridge deck drains. Include with **6-02.3(10)D.OPT12.GB6**, and either **6-02.4.OPT32.GB6** and **6-02.5.OPT58.GB6**, or **6-02.5.OPT59.FB6**.

[6-02.2.OPT60.GB6](#)

(Seismic Retrofit Materials)  
(April 6, 2015)

Use in projects with seismic retrofit construction.  
Must use once preceding any of the following:

[6-02.2.OPT60\(B\).GB6](#)

(Steel and PVC Pipe)  
(April 6, 2015)

Use in projects with seismic retrofit work when steel and/or PVC pipe are used as materials. Include with **6-02.4.OPT44.FB6** and **6-02.5.OPT72.GB6**, and all other applicable seismic retrofit GSPs supplementing Sections 6-02.2 and 6-02.3.

[6-02.2.OPT60\(C\).GB6](#)

(Structural Steel and Steel Fastening Hardware)  
(November 20, 2023)

Use in projects with seismic retrofit work when structural steel and steel fastening hardware are used as materials. Include with **6-02.4.OPT44.FB6** and **6-02.5.OPT72.GB6**, and all applicable other seismic retrofit GSPs supplementing Sections 6-02.2 and 6-02.3.

[6-02.2.OPT60\(D\).GB6](#)

(High-Strength Steel Rods)  
(September 8, 2020)

Use in projects with seismic retrofit work requiring the installation of longitudinal seismic restrainer assemblies. Include with **6-02.3.OPT8(L).GB6**, **6-02.4.OPT44.FB6** and **6-02.5.OPT72.GB6**, and all other applicable seismic retrofit GSPs supplementing Sections 6-02.2 and 6-02.3.

[6-02.2.OPT60\(F\).GB6](#)

(Column Jacketing Materials)  
(September 8, 2020)

Use in projects with seismic retrofit work when column jacketing is required. Include with **6-02.3.OPT8(C).GB6**, **6-02.3.OPT8(D).GB6**, **6-02.3.OPT8(E).GB6**, **6-02.3.OPT8(M).GB6**, **6-02.4.OPT45.FB6**, **6-02.5.OPT73.GB6**, and **6-03.3(30).OPT1.FB6**. Include with **6-02.3.OPT8(F).FB6** when the pre-fabrication field measuring requirements for specific existing bridge columns are waived.

[6-02.2.OPT61.GB6](#)

(PCPS Conc. SIP Panels)  
(September 8, 2020)

Use in projects with precast prestressed concrete stay-in-place panels. Include with **6-02.3(9)A.OPT6.GB6**, **6-**

1                                    **02.3(9)E.OPT6.GB6,    6-02.3(9)F.OPT1.GB6,    6-**  
2                                    **02.3(9)G.OPT6.GB6 and 6-02.3(9)I.OPT6.GB6.**

3  
4                    **6-02.2(9-06.4).GR6**            (Resin Bonded Anchor System)  
5                                    (Item number 2 of the first paragraph of Section 9-06.4 is  
6                                    revised to read)  
7                                    Must use once preceding any of the following:  
8

9                    **6-02.2(9-06.4).OPT1.2026.GR6** (Resin Bonding Material)  
10                                    (May 5, 2025)  
11                                    Use in projects with resin bonded anchors.

12  
13                    **6-02.3.GR6**                                    **Construction Requirements**

14  
15                    **6-02.3.INST1.GR6**                                    (Section 6-02.3 is supplemented with the following)  
16                                    Must use once preceding any of the following:  
17

18                    **6-02.3.OPT1.GB6**                                    (Epoxy Crack Sealing)  
19                                    (September 7, 2021)  
20                                    Use in projects which require sealing cracks in existing  
21                                    concrete with injected epoxy resin. Include with **6-**  
22                                    **02.2.OPT4.GB6,    6-02.4.OPT24.GB6,    and    6-**  
23                                    **02.5.OPT49.GB6.**  
24

25                    **6-02.3.OPT2.GB6**                                    (Bridge Supported Utilities)  
26                                    Must use once preceding any of the following:  
27

28                    **6-02.3.OPT2(A).GB6**                                    (Bridge Supported Utilities)  
29                                    (August 3, 2015)  
30                                    Use in projects with bridge supported utilities when the  
31                                    supports include concrete inserts. Include with **6-**  
32                                    **02.2.OPT46.GB6,    6-02.4.OPT1.FB6,    and    6-**  
33                                    **02.5.OPT26.FB6.**  
34

35                    **6-02.3.OPT2(B).GB6**                                    (Bridge Supported Utilities)  
36                                    (June 26, 2000)  
37                                    Use in projects with bridge supported utilities when the  
38                                    Contractor furnishes and installs the supports and the  
39                                    utility pipe or conduit pipe. Include with **6-**  
40                                    **02.5.OPT92.FB6** and other applicable bridge  
41                                    supported utility material GSP's. Include with **6-**  
42                                    **02.2.OPT46(A).GB6,    6-02.3.OPT2(A).GB6,    6-**  
43                                    **02.4.OPT1.FB6, and 6-02.5.OPT26.FB6** when the  
44                                    supports include concrete inserts.  
45

46                    **6-02.3.OPT2(C).FB6**                                    (Bridge Supported Utilities)  
47                                    (June 26, 2000)  
48                                    Use in projects with bridge supported utilities when the  
49                                    Utility Company furnishes, or furnishes and installs,  
50                                    some of the supports and pipe for the utilities. The first  
51                                    fill-in specifies the items to be furnished and installed  
52                                    by the Utility Company. The second and third fill-ins  
53                                    specify the items to be installed by the Contractor

which are furnished by either the Utility Company or the Contractor. Include with **6-02.5.OPT92.FB6** and **6-02.5.OPT93.GB6**, and other applicable bridge supported utility material GSP's. Include with **6-02.2.OPT46(A).GB6**, **6-02.3.OPT2(A).GB6**, **6-02.4.OPT1.FB6**, and **6-02.5.OPT26.FB6** when the supports include concrete inserts.  
(3 fill-ins)

[6-02.3.OPT8.GB6](#)

(Seismic Retrofit)

Must use once preceding one of the following:

[6-02.3.OPT8\(B\).GB6](#)

(Seismic Retrofit Demolition Plan)

(April 6, 2015)

Use in seismic retrofit projects where removal of portions of existing concrete and steel reinforcing bars, or cleaning and preparing of existing concrete surfaces is required. Include with **6-02.4.OPT44.FB6**, **6-02.3.OPT8(H).GB6**, and **6-02.5.OPT72.GB6**, and all other applicable seismic retrofit GSPs supplementing Sections 6-02.2 and 6-02.3.

[6-02.3.OPT8\(C\).GB6](#)

(Column Jacket Installation Plan)

(April 6, 2015)

Use in projects with column jacketing of existing bridges. Include with **6-02.2.OPT60(F).GB6**, **6-02.3.OPT8(D).GB6**, **6-02.3.OPT8(E).GB6**, **6-02.3.OPT8(M).GB6**, **6-02.4.OPT45.FB6**, **6-02.5.OPT73.GB6**, and **6-03.3(30).OPT1.FB6**. Include with **6-02.3.OPT8(F).FB6** when the pre-fabrication field measuring requirements for specific existing bridge columns are waived.

[6-02.3.OPT8\(D\).GB6](#)

(Column Jacket Shop Drawings)

(April 6, 2015)

Use in projects with column jacketing of existing bridges. Include with **6-02.2.OPT60(F).GB6**, **6-02.3.OPT8(C).GB6**, **6-02.3.OPT8(E).GB6**, **6-02.3.OPT8(M).GB6**, **6-02.4.OPT45.FB6**, **6-02.5.OPT73.GB6**, and **6-03.3(30).OPT1.FB6**. Include with **6-02.3.OPT8(F).FB6** when the pre-fabrication field measuring requirements for specific existing bridge columns are waived.

[6-02.3.OPT8\(E\).GB6](#)

(Field Measuring Existing Bridge Columns)

(September 8, 2020)

Use in projects where field measuring of existing bridge columns is required. Include with **6-02.2.OPT60(F).GB6**, **6-02.3.OPT8(C).GB6**, **6-02.3.OPT8(D).GB6**, **6-02.3.OPT8(M).GB6**, **6-02.4.OPT45.FB6**, **6-02.5.OPT73.GB6**, and **6-03.3(30).OPT1.FB6**. Include with **6-02.3.OPT8(F).FB6** when the pre-fabrication field

measuring requirements for specific existing bridge columns are waived.

[6-02.3.OPT8\(F\).FB6](#)

(Field Measuring Waiver for Specific Existing Bridge Columns)  
(April 6, 2015)

Use in projects where the requirement of pre-fabrication field measuring of specific existing bridge columns is waived. The fill-in specifies the bridge(s) and pier(s) where the column receiving the waiver is located. Include with **6-02.2.OPT60(F).GB6**, **6-02.3.OPT8(C).GB6**, **6-02.3.OPT8(D).GB6**, **6-02.3.OPT8(E).GB6**, **6-02.3.OPT8(M).GB6**, **6-02.4.OPT45.FB6**, **6-02.5.OPT73.GB6**, and **6-03.3(30).OPT1.FB6**.  
(1 fill-in)

[6-02.3.OPT8\(G\).FB6](#)

(Field Measuring for Seismic Retrofit Components)  
(April 6, 2015)

Use in projects where field measuring of existing bridge members is required for seismic retrofit components. The first fill-in specifies the bridge(s) where the field measuring work is required. The second fill-in specifies the members or components to be measured. Include with **6-02.4.OPT44.FB6** and **6-02.5.OPT72.GB6**, and all other applicable seismic retrofit GSPs supplementing Sections 6-02.2 and 6-02.3.  
(2-fill-ins)

[6-02.3.OPT8\(H\).GB6](#)

(Removing Portions of Existing Concrete)  
(April 6, 2015)

Use in seismic retrofit projects where removal of portions of existing concrete and steel reinforcing bars, or cleaning and preparing of existing concrete surfaces is required. Include with **6-02.3.OPT8(B).GB6**, **6-02.4.OPT44.FB6** and **6-02.5.OPT72.GB6**, and all other applicable seismic retrofit GSPs supplementing Sections 6-02.2 and 6-02.3.

[6-02.3.OPT8\(J\).GB6](#)

(Drilling Holes and Setting Steel Reinf. Bars, and Placing Concrete)  
(April 6, 2015)

Use in seismic retrofit projects requiring the construction of catcher blocks, girder stops, and other concrete appendages. Include with **6-02.3.OPT8(B).GB6**, **6-02.3.OPT8(H).GB6**, **6-02.3(24)C.OPT1.GB6**, **6-02.4.OPT44.FB6**, and **6-02.5.OPT72.GB6**, and all other applicable seismic retrofit GSPs supplementing Sections 6-02.2 and 6-02.3.

[6-02.3.OPT8\(K\).GB6](#) (Installing and Tensioning High-Strength Steel Bar Reinforcement)  
(April 6, 2015)  
Use in seismic retrofit projects requiring the installation, stressing, and grouting of high-strength steel bar reinforcement. Include with **6-02.4.OPT44.FB6** and **6-02.5.OPT72.GB6**, and all other applicable seismic retrofit GSPs supplementing Sections 6-02.2 and 6-02.3.

[6-02.3.OPT8\(L\).GB6](#) (Longitudinal Seismic Restrainers)  
(November 20, 2023)  
Use in seismic retrofit projects requiring the installation of longitudinal seismic restrainer assemblies. Include with **6-02.2.OPT60(B).GB6**, **6-02.2.OPT60(C).BSP.GB6**, **6-02.2.OPT60(D).GB6**, either **6-02.4.OPT43.GB6** and **6-02.5.OPT71.GB6**, or **6-02.4.OPT44.FB6** and **6-02.5.OPT72.GB6**, and all other applicable seismic retrofit GSPs supplementing Sections 6-02.2 and 6-02.3.

[6-02.3.OPT8\(M\).GB6](#) (Column Jacketing)  
(September 8, 2020)  
Use in projects with column jacketing of existing bridges. Include with **6-02.2.OPT60(F).GB6**, **6-02.3.OPT8(C).GB6**, **6-02.3.OPT8(D).GB6**, **6-02.3.OPT8(E).GB6**, **6-02.4.OPT45.FB6**, **6-02.5.OPT73.GB6**, and **6-03.3(30).OPT1.FB6**. Include with **6-02.3.OPT8(F).FB6** when the pre-fabrication field measuring requirements for specific existing bridge columns are waived.

[6-02.3.OPT9.GB6](#) (Polyester Concrete)  
(January 7, 2019)  
Use in projects where polyester concrete is required. Include with **6-02.2.OPT27.GB6**.

[6-02.3.OPT10.GB6](#) (Elastomeric Concrete)  
(January 7, 2019)  
Use in projects where elastomeric concrete is required. Include with **6-02.2.OPT28.GB6**.

#### [6-02.3\(2\).GR6](#) **Proportioning Materials**

[6-02.3\(2\).INST1.GR6](#) (Section 6-02.3(2) is supplemented with the following)  
Must use once preceding any of the following:

[6-02.3\(2\).OPT1.GB6](#) (Expansion Joint Header Concrete)  
(September 8, 2020)  
Use in projects with expansion joint modifications where the headers for the modified joints are made of a high early strength concrete mix. Include with **6-**

02.2.OPT2.GB6, 6-02.3(24)C.OPT1.GB6, 6-02.3(13).OPT7(H).GB6, , or 6-02.4.OPT8.FB6 and 6-02.5.OPT33.GB6, and all other applicable expansion joint modification GSPs supplementing Sections 6-02.2 and 6-02.3(13).

**6-02.3(4).GR6**

**Ready-Mix Concrete**

**6-02.3(4)D.GR6**

**Temperature and Time for Placement**

6-02.3(4)D.INST1.GR6 (Section 6-02.3(4)D is revised to read)  
Must use once preceding any of the following:

6-02.3(4)D.OPT1.2026.GR6 (Temperature and Time for Placement)  
(March 20, 2025)  
Use in projects with ready-mix concrete.

**6-02.3(6).GR6**

**Placing Concrete**

**6-02.3(6)B.GR6**

**Placing Concrete in Foundation Seals**

6-02.3(6)B.INST1.GR6 (Section 6-02.3(6)B is supplemented with the following)  
Must use once preceding any of the following:

6-02.3(6)B.OPT1.GB6 (Concrete Seals)  
(June 26, 2000)  
Use in projects where there is the possibility of seals being omitted during construction, in which case the footing is to be lowered to bottom of seal.

6-02.3(6)B.OPT2.GB6 (Concrete Seals)  
(June 26, 2000)  
Use in projects where there is the possibility of seals being omitted during construction, in which case the footing is not to be lowered.

**6-02.3(9).GR6**

**Precast Concrete Panels**

**6-02.3(9)A.GR6**

**Shop Drawings**

6-02.3(9)A.INST2.GR6 (The list included in the third paragraph of Section 6-02.3(9)A is supplemented with the following)  
Must use once preceding any of the following:

6-02.3(9)A.OPT6.GB6 (PCPS Conc. SIP Panels)  
(September 8, 2020)  
Use in projects with precast prestressed concrete stay-in-place panels. Include with 6-02.2.OPT61.GB6, 6-02.3(9)E.OPT6.GB6, 6-02.3(9)F.OPT1.GB6, 6-02.3(9)G.OPT6.GB6 and 6-02.3(9)I.OPT6.GB6.

**6-02.3(9)E.GR6**

**Finishing**

**6-02.3(9)E.INST1.GR6**

(Section 6-02.3(9)E is supplemented with the following)  
Must use once preceding any of the following:

**6-02.3(9)E.OPT6.GB6**

(PCPS Conc. SIP Panels)  
(September 8, 2020)  
Use in projects with precast prestressed concrete stay-in-place panels. Include with **6-02.2.OPT61.GB6**, **6-02.3(9)A.OPT6.GB6**, **6-02.3(9)F.OPT1.GB6**, **6-02.3(9)G.OPT6.GB6** and **6-02.3(9)I.OPT6.GB6**.

**6-02.3(9)F.GR6**

**Tolerances**

**6-02.3(9)F.INST1.GR6**

(Section 6-02.3(9)F is supplemented with the following)  
Must use once preceding any of the following:

**6-02.3(9)F.OPT1.GB6**

(PCPS Conc. SIP Panels)  
(September 8, 2020)  
Use in projects with precast prestressed concrete stay-in-place panels. Include with **6-02.2.OPT61.GB6**, **6-02.3(9)A.OPT6.GB6**, **6-02.3(9)E.OPT6.GB6**, **6-02.3(9)G.OPT6.GB6** and **6-02.3(9)I.OPT6.GB6**.

**6-02.3(9)G.GR6**

**Handling and Storage**

**6-02.3(9)G.INST1.GR6**

(Section 6-02.3(9)G is supplemented with the following)  
Must use once preceding any of the following:

**6-02.3(9)G.OPT6.GB6**

(PCPS Conc. SIP Panels)  
(September 8, 2020)  
Use in projects with precast prestressed concrete stay-in-place panels. Include with **6-02.2.OPT61.GB6**, **6-02.3(9)A.OPT6.GB6**, **6-02.3(9)E.OPT6.GB6**, **6-02.3(9)F.OPT1.GB6** and **6-02.3(9)I.OPT6.GB6**.

**6-02.3(9)I.GR6**

**Erection**

**6-02.3(9)I.INST1.GR6**

(Section 6-02.3(9)I is supplemented with the following)  
Must use once preceding any of the following:

**6-02.3(9)I.OPT6.GB6**

(PCPS Conc. SIP Panels)  
(September 8, 2020)  
Use in projects with precast prestressed concrete stay-in-place panels. Include with **6-**

02.2.OPT61.GB6, 6-02.3(9)A.OPT6.GB6, 6-02.3(9)E.OPT6.GB6, 6-02.3(9)F.OPT1.GB6 and 6-02.3(9)G.OPT6.GB6.

**6-02.3(10).GR6**

**Bridge Decks and Bridge Approach Slabs**

**6-02.3(10)D.GR6**

**Concrete Placement, Finishing, and Texturing**

6-02.3(10)D.INST1.GR6 (Section 6-02.3(10)D is supplemented with the following)  
Must use once preceding any of the following:

6-02.3(10)D.OPT1.GB6 (Repairing Slab Left Exposed After Removing Existing Curb or Sidewalk)  
(August 4, 2008)  
Use in projects when existing curbs or sidewalks are to be removed and the portion of the slab under the curb or sidewalk that is to remain exposed will be within two feet from the traffic lane.

6-02.3(10)D.OPT2.GB6 (Repairing Slab Left Exposed After Removing Existing Curb or Railbase)  
(August 4, 2008)  
Use in projects when existing curbs or railbases are to be removed and the portion of the slab under the curb or railbase that is to remain exposed will be more than two feet from the traffic lane.

6-02.3(10)D.OPT3.GB6 (Bridge Drain Risers)  
(August 3, 2015)  
Use in projects requiring the raising of bridge drains prior to asphalt or modified concrete overlay work on bridge decks. Include with **6-02.2.OPT48.GB6**. Include with **6-02.3(10)D.OPT4.GB6** if the bridge deck is overlaid with membrane waterproofing and ACP. Include with **6-02.5.OPT53.FB6** if the work is included in the cost of the membrane waterproofing or modified concrete overlay. Include with **6-02.4.OPT26.GB6** and **6-02.5.OPT51.GB6** if the unit contract bid item "Modify Bridge Drain" is used to pay for the work.  
Must use once preceding any of the following:

6-02.3(10)D.OPT3(A).GB6 (Bridge Drain Risers)  
(August 4, 2008)  
Use in projects requiring the raising of bridge drains prior to membrane waterproofing and asphalt overlay work. Include with **6-02.2.OPT48.GB6** and **6-**

**02.3(10)D.OPT3.GB6.** Include with **6-02.5.OPT53.FB6** if the work is included in the cost of the membrane waterproofing. Include with **6-02.4.OPT26.GB6** and **6-02.5.OPT51.GB6** if the unit contract bid item "Modify Bridge Drain" is used to pay for the work.

**6-02.3(10)D.OPT5.GB6** (Plugging Existing Bridge Drain)  
(August 3, 2015)

Use in projects requiring plugging of bridge drains. Include with **6-02.5.OPT53.FB6** if the work is included in the cost of the membrane waterproofing or modified concrete overlay. Include with **6-02.4.OPT27.GB6** and **6-02.5.OPT52.GB6** if the unit contract bid item "Plugging Existing Bridge Drain" is used to pay for the work.

**6-02.3(10)D.OPT12.GB6** (Core Drilled Bridge Deck Drain)  
(April 6, 2015)

Use in projects with core drilled bridge deck drains. Include with **6-02.2.OPT58.GB6**, and either **6-02.4.OPT32.GB6** and **6-02.5.OPT58.GB6**, or **6-02.5.OPT59.FB6**.

**6-02.3(10)F.GR6**                      **Bridge Approach Slab Orientation and Anchors**

**6-02.3(10)F.INST1.GR6** (Section 6-02.3(10)F is supplemented with the following)  
Must use once preceding any of the following:

**6-02.3(10)F.OPT2.GB6** (Construct pavement end of approach slabs parallel to pavement seat)  
(August 4, 2008)  
Use in projects when the pavement ends of all approach slabs are constructed parallel to the pavement seat.

**6-02.3(10)F.OPT3.FB6** (Construct pavement end of approach slabs both normal to the roadway centerline and parallel to pavement seat)  
(August 4, 2008)  
Use in projects when the pavement ends of the approach slabs are constructed both normal to the roadway centerline and parallel to the pavement seat.  
(2 fill-ins)

**6-02.3(13).GR6**                      **Expansion Joints**

**6-02.3(13).INST1.GR6** (Section 6-02.3(13) is supplemented with the

following)

Must use once preceding any of the following:

6-02.3(13).OPT7.GB6 Expansion Joint Modification

6-02.3(13).OPT7(B).GB6 (Expansion Joint Demolition Plan)

(April 6, 2015)

Use in projects where removal of portions of the existing bridge expansion joint assembly, and/or adjacent concrete and steel reinforcing bars, is required. Include with **6-02.3(13).OPT7(E).FB6**, **6-02.4.OPT8.FB6** and **6-02.5.OPT33.GB6**, and all other applicable expansion joint modification GSPs supplementing Sections 6-02.2 and 6-02.3(13).

6-02.3(13).OPT7(C).GB6 (Joint Preparation and Installation Procedure)

(April 6, 2015)

Use in projects where rapid cure silicone sealant is used for expansion joint modification. Include with **6-02.2.OPT26.GB6**, either **6-02.3(13).OPT7(I).GB6** or **6-02.3(13).OPT7(J).GB6**, **6-02.4.OPT8.FB6** and **6-02.5.OPT33.GB6**, and all other applicable expansion joint modification GSPs supplementing Sections 6-02.2 and 6-02.3(13).

6-02.3(13).OPT7(D).FB6 (Field Measuring Existing Expansion Joint)

(April 6, 2015)

Use in projects where field measuring of the existing expansion joint is required. The fill-in specifies the bridge(s) included in the field measuring requirement. Include with **6-02.4.OPT8.FB6** and **6-02.5.OPT33.GB6**, and all other applicable expansion joint modification GSPs supplementing Sections 6-02.2 and 6-02.3(13).  
(1 fill-in)

6-02.3(13).OPT7(E).FB6 (Removing Portions of Existing Bridge Expansion Joints)

(April 6, 2015)

Use in projects where removal of portions of the existing bridge expansion joint assembly, and/or adjacent concrete and steel reinforcing bars, is required. The fill-in specified the bridge(s) where the expansion joint removal work is required. Include with **6-02.3(13).OPT7(B).GB6**, **6-02.4.OPT8.FB6** and **6-02.5.OPT33.GB6**, and all other applicable expansion joint modification

GSPs supplementing Sections 6-02.2 and 6-02.3(13).  
(1-fill-in)

6-02.3(13).OPT7(F).GB6 (Drilling Holes and Setting St. Reinf. Bars)

(April 6, 2015)

Use in projects with expansion joint modification where drilling holes and setting steel reinforcing bar dowels are required. Include with **6-02.2.OPT2.GB6**, **6-02.3(24)C.OPT1.GB6**, **6-02.4.OPT8.FB6** and **6-02.5.OPT33.GB6**, and all other applicable expansion joint modification GSPs supplementing Sections 6-02.2 and 6-02.3(13).

6-02.3(13).OPT7(G).GB6 (Placing Polyester Concrete or Elastomeric Concrete Headers)

(April 6, 2015)

Use in projects when the headers for modified bridge expansion joints are made of either polyester concrete or elastomeric concrete. Include with either **6-02.2.OPT27.GB6** and **6-02.3.OPT9.GB6**, or **6-02.2.OPT28.GB6** and **6-02.3.OPT10.GB6**, **6-02.4.OPT8.FB6** and **6-02.5.OPT33.GB6**, and all other applicable expansion joint modification GSPs supplementing Sections 6-02.2 and 6-02.3(13).

6-02.3(13).OPT7(H).GB6 (Placing Concrete Headers)

(September 8, 2020)

Use in projects where the headers for modified bridge expansion joints are made of concrete. Include with **6-02.2.OPT2.GB6**, **6-02.3(24)C.OPT1.GB6**, **6-02.3(13).OPT7(F).GB6**, **6-02.3(2).OPT1.GB6**, **6-02.4.OPT8.FB6** and **6-02.5.OPT33.GB6**, and all other applicable expansion joint modification GSPs supplementing Sections 6-02.2 and 6-02.3(13).

6-02.3(13).OPT7(I).GB6 (Placing Expansion Joint Sealant)

(September 8, 2020)

Use in projects where rapid cure silicone sealant is used for modified bridge expansion joints with concrete or polymer concrete or polyester concrete or elastomeric concrete headers. Include with **6-02.2.OPT26.GB6**, **6-02.3(13).OPT7(C).GB6**, **6-02.4.OPT8.FB6** and **6-02.5.OPT33.GB6**, and all other applicable expansion joint modification GSPs supplementing Sections 6-02.2 and 6-02.3(13).

6-02.3(13).OPT7(J).GB6 (Placing Expansion Joint Sealant)

(September 8, 2020)

Use in projects where rapid cure silicone sealant is used for modified bridge expansion joints with modified concrete overlay headers. To be used only for bridges with low ADT, and only with the approval of the Bridge and Structures Office Bearing and Expansion Joint Specialist. Include with **6-02.2.OPT26.GB6**, **6-02.3(13).OPT7(C).GB6**, **6-02.4.OPT8.FB6** and **6-02.5.OPT33.GB6**, and all other applicable expansion joint modification GSPs supplementing Sections 6-02.2 and 6-02.3(13) and the pertinent modified concrete overlay GSPs.

#### **6-02.3(13)C.GR6**

#### **Modular Expansion Joint System**

**6-02.3(13)C.INST1.GR6** (Section 6-02.3(13)C is supplemented with the following)  
Must use once preceding any of the following:

**6-02.3(13)C.OPT1.FB6** (Acceptable Manufacturers)  
(September 8, 2020)  
Include in projects requiring a modular expansion joint system. The fill-in specifies the percentage of the amplified vertical load range to be used for the horizontal load range for the fatigue design. The fill-in value shall be 20-percent except for installations at locations subject to significant braking and acceleration forces or subject to particularly large movement ranges where the fill-in value shall be 50-percent. Coordination with the Bridge and Structures Office Bridge Bearing and Expansion Joint Specialist is required.  
Include with **6-02.4.OPT3.FB6** and **6-03.3(30).FB6**.  
(1-fill-in)

#### **6-02.3(14).GR6**

#### **Finishing Concrete Surfaces**

#### **6-02.3(14)C.GR6**

#### **Pigmented Sealer for Concrete Surfaces**

**6-02.3(14)C.INST1.GR6** (Section 6-02.3(14)C is supplemented with the following)  
Must use once preceding any of the following:

**6-02.3(14)C.OPT1.GB6** (Washington Gray Pigmented Sealer)  
(April 6, 2009)  
Use in projects requiring application of pigmented sealer to concrete surfaces, with Washington Gray being the sole color.

**6-02.3(14)C.OPT2.GB6** (Mt. St. Helens Gray Pigmented Sealer)  
(April 6, 2009)

Use in projects requiring application of pigmented sealer to concrete surfaces, with Mt. St. Helens Gray being the sole color.

[6-02.3\(14\)C.OPT3.GB6](#) (Mt. Baker Gray Pigmented Sealer)  
(April 6, 2009)

Use in projects requiring application of pigmented sealer to concrete surfaces, with Mt. Baker Gray being the sole color.

[6-02.3\(14\)C.OPT4.GB6](#) (Cascade Green Pigmented Sealer)  
(April 6, 2009)

Use in projects requiring application of pigmented sealer to concrete surfaces, with Cascade Green being the sole color.

[6-02.3\(14\)C.OPT5.FB6](#) (Multiple Color Pigmented Sealer)  
(April 6, 2009)

Use in projects requiring application of pigmented sealer to concrete surfaces, with two or more colors specified. Each fill-in pair is to be used to specify the structural features receiving a specific color of pigmented sealer.  
(2 fill-ins)

#### **6-02.3(17).GR6**

#### **Falsework and Formwork**

#### **6-02.3(17)C.GR6**

#### **Falsework and Formwork at Special Locations**

[6-02.3\(17\)C.INST1.GR6](#) (Section 6-02.3(17)C is supplemented with the following)  
Must use once preceding any of the following:

[6-02.3\(17\)C.OPT1.FB6](#) (Falsework Adjacent to or over Railroad Tracks)  
(October 3, 2022)  
Use in bridge projects requiring falsework adjacent to or over railroad tracks.  
(1 fill-in)  
Contact the Railroad Liaison Engineer (360) 705-7271 for the fill in information.

#### **6-02.3(17)K.GR6**

#### **Concrete Forms on Steel Spans**

[6-02.3\(17\)K.INST1.GR6](#) (The first paragraph of Section 6-02.3(17)K is revised to read as follows)  
Must use once preceding any of the following:

[6-02.3\(17\)K.OPT1.GB6](#) (Stay-in-place Metal forms for Steel Box Girders)  
(August 3, 2015)  
Use in projects with steel box girder bridges when stay-in-place metal forms are allowed by the Bridge and Structures Office Steel Specialist.

1 Include with **6-02.4.OPT1.FB6**, **6-**  
2 **02.5.OPT26.FB6**, **6-03.3(28)B.OPT1.GB6**, **6-**  
3 **03.3(30).OPT1.FB6**, **6-03.3(39).OPT1.GB6**, and  
4 **6-03.4.OPT1.FB6**.

5  
6 **6-02.3(24).GR6**

**Reinforcement**

7  
8 **6-02.3(24)C.GR6**

**Placing and Fastening**

9  
10 **6-02.3(24)C.INST1.GR6** (Section 6-02.3(24)C is supplemented with  
11 the following)  
12 Must use once preceding any of the following:

13  
14 **6-02.3(24)C.OPT1.GB6** (Drilling Holes for, and Setting, Steel Reinforcing  
15 Bar Dowels)  
16 (September 8, 2020)  
17 Use in projects where holes are drilled into  
18 existing concrete and steel reinforcing bar  
19 dowels are set with epoxy resin. Include with **6-**  
20 **02.2.OPT2.GB6**. Include the above with **2-**  
21 **02.1.OPT3.GR2**, **2-02.3(2).OPT12.GR2**, and **2-**  
22 **02.5.OPT7.GR2** when extending a conc. box  
23 culvert.  
24

25 **6-02.3(25).GR6**

**Prestressed Concrete Girders**

26  
27 **6-02.3(25)L.GR6**

**Handling and Storage**

28  
29 **6-02.3(25)L2.GR6**

**Girder Lateral Stability and Stress Analysis**

30  
31 **6-02.3(25)L2.INST1.GR6** (The table in item number 4 of the first paragraph  
32 is revised to read)  
33 Must use once preceding any of the following.

34  
35 **6-02.3(25)L2.OPT1.2026.GR6** (Prestressed Concrete Girder  
36 Stresses)  
37 (January 6, 2025)  
38 Use in projects with prestressed concrete  
39 girders.  
40

41 **6-02.3(26).GR6**

**Cast-in-Place Prestressed Concrete**

42  
43 **6-02.3(26).INST1.GR6** (The third paragraph of Section 6-02.3(26) is  
44 revised to  
45 read as follows)  
46 Must use once preceding any of the following:

47  
48 **6-02.3(26).OPT1.GB6** (Cast-in-Place Prestressed Concrete)  
49 (January 4, 2010)  
50 Use in projects with segmental post-tensioned  
51 structures. Check with the Region Construction  
52 Engineer to see if testing equipment is available.  
53

## **6-02.4.GR6**

### **Measurement**

#### **6-02.4.INST1.GR6**

(Section 6-02.4 is supplemented with the following)  
Must use once preceding any of the following:

#### **6-02.4.OPT1.FB6**

(Summary of Quantities for Superstructure and Bridge Deck)  
(September 8, 2020)  
Use in bridge construction projects with lump sum items for superstructure or bridge deck. The first and third fill-in specify the appropriate bid item name ("Superstructure - \_\_\_\_\_" or "Bridge Deck - \_\_\_\_\_"). The second fill-in itemizes the approximate quantities included. Include with **6-02.5.OPT26.FB6** when the "Bridge Deck - \_\_\_\_\_" bid item is used.  
(3 fill-ins)

#### **6-02.4.OPT3.FB6**

(Modular Expansion Joint System)  
(September 8, 2020)  
Include in projects requiring a modular expansion joint system. The fill-in is to itemize the quantities of work and materials included in the lump sum item. Coordination with the Bridge and Structures Office Bearing and Expansion Joint Specialist is required. Include with **6-02.3(13)C.OPT1.FB6** and **6-03.3(30).OPT1.FB6**.  
(1 fill-in)

#### **6-02.4.OPT8.FB6**

(Expansion Joint Modification)  
(September 8, 2020)  
Use in projects with lump sum item for expansion joint modification. The fill-in specifies the approximate quantities included. Include with **6-02.5.OPT33.GB6** and all applicable expansion joint modification GSPs supplementing Sections 6-02.2 and 6-02.3(13).  
(1 fill-in)

#### **6-02.4.OPT24.GB6**

(Epoxy Crack Sealing)  
(August 6, 2012)  
Use in projects which require sealing cracks in existing concrete with injected epoxy resin. Include with **6-02.2.OPT4.GB6**, **6-02.3.OPT1.GB6**, and **6-02.5.OPT49.GB6**.

#### **6-02.4.OPT26.GB6**

(Modifying Bridge Drain)  
(June 26, 2000)  
Use in projects where modifying bridge drains is a stand-alone bid item. Include with **6-02.2.OPT48.GB6**, **6-02.3(10)D.OPT3.GB6**, and **6-02.5.OPT51.GB6** with modified concrete overlay projects. Include the above with **6-02.3(10)D.OPT4.GB6** with membrane waterproofing and ACP overlay projects.

#### **6-02.4.OPT27.GB6**

(Plugging Existing Bridge Drain)

(June 26, 2000)  
Use in projects where plugging existing bridge drains is a stand-alone bid item. Include with **6-02.3(10)D.OPT5.GB6** and **6-02.5.OPT52.GB6**.

[6-02.4.OPT32.GB6](#)

(Core Drilled Bridge Deck Drain)  
(April 6, 2015)  
Use in projects where core drilled bridge deck drain is a stand-alone bid item. Include with **6-02.2.OPT58.GB6**, **6-02.3(10)D.OPT12.GB6**, and **6-02.5.OPT58.GB6**.

[6-02.4.OPT43.GB6](#)

(Longitudinal Seismic Restrainer)  
(April 6, 2015)  
Use in projects where longitudinal seismic restrainer is a stand-alone bid item. Include with **6-02.2.OPT60(B).GB6**, **6-02.2.OPT60(C).GB6**, **6-02.2.OPT60(D).GB6**, **6-02.3.OPT8(L).GB6**, **6-02.5.OPT71.GB6** and all other applicable seismic retrofit GSPs supplementing Sections 6-02.2 and 6-02.3.

[6-02.4.OPT44.FB6](#)

(Seismic Retrofit)  
(September 8, 2020)  
Use in projects with a lump sum item for seismic retrofit. The fill-in specifies the approximate quantities included. Include with **6-02.5.OPT72.GB6** and all other applicable seismic retrofit GSPs supplementing Sections 6-02.2 and 6-02.3.  
(1 fill-in)

[6-02.4.OPT45.FB6](#)

(Column Jacketing)  
(September 8, 2020)  
Use in projects with a lump sum item for column jacketing. The fill-in specifies the approximate quantities included. Include with **6-02.2.OPT60(F).GB6**, **6-02.3.OPT8(C).GB6**, **6-02.3.OPT8(D).GB6**, **6-02.3.OPT8(E).GB6**, **6-02.3.OPT8(M).GB6**, **6-02.5.OPT73.GB6**, and **6-03.3(30).OPT1.FB6**. Include with **6-02.3.OPT8(F).FB6** when the pre-fabrication field measuring requirements for specific existing bridge columns are waived.  
(1 fill-in)

[6-02.5.GR6](#)

**Payment**

[6-02.5.INST3.GR6](#)

(The fifth and sixth bid items under Section 6-02.5 are supplemented with the following)  
Must use once preceding any of the following:

[6-02.5.OPT20.GB6](#)

(Epoxy-coated St. Reinf. Bar for Bridge)  
(April 6, 2015)  
Use in projects with small amounts of epoxy-coated steel reinforcing bar in bridge substructure which is included in the quantity for "St. Reinf. Bar for Bridge" in lieu of a separate stand-alone bid item.

[6-02.5.INST4.GR6](#)

(Section 6-02.5 is supplemented with the following)  
Must use once preceding any of the following:

[6-02.5.OPT26.FB6](#)

(Bridge Deck)  
(August 2, 2010)  
Use in steel bridge construction projects with lump sum items for bridge deck. The fill-in specifies work items included in the bid item. Include with **6-02.4.OPT1.FB6**.  
(1 fill-in)

[6-02.5.OPT33.GB6](#)

(Expansion Joint Modification)  
(April 6, 2015)  
Use in projects where expansion joint modification is a lump sum item. Include with **6-02.4.OPT8.FB6** and all applicable expansion joint modification GSPs supplementing Sections 6-02.2 and 6-02.3(13).

[6-02.5.OPT49.GB6](#)

(Epoxy Crack Sealing)  
(August 1, 2011)  
Use in projects which require sealing cracks in existing concrete with injected epoxy resin. Include with **6-02.2.OPT4.GB6**, **6-02.3.OPT1.GB6**, and **6-02.4.OPT24.GB6**.

[6-02.5.OPT51.GB6](#)

(Modify Bridge Drain)  
(June 26, 2000)  
Use in projects where modifying bridge drains is a stand-alone bid item. Include with **6-02.2.OPT48.GB6**, **6-02.3(10)D.OPT3.GB6**, and **6-02.4.OPT26.GB6** with modified concrete overlay projects. Include the above with **6-02.3(10)D.OPT4.GB6** with waterproof membrane and HMA overlay projects.

[6-02.5.OPT52.GB6](#)

(Plugging Existing Bridge Drain)  
(June 26, 2000)  
Use in projects where plugging existing bridge drains is a stand-alone bid item. Include with **6-02.3(10)D.OPT5.GB6** and **6-02.4.OPT27.GB6**.

[6-02.5.OPT53.FB6](#)

(Modifying or Plugging Existing Bridge Drain)  
(June 26, 2000)  
Use in projects where payment for modifying or plugging existing bridge drains is included under either "Waterproof Membrane" or "Finishing and Curing Modified Conc. Overlay". The first fill-in specifies whether the work is modifying or plugging existing bridge drains. The second fill-in specifies appropriate pay item for the work. Include with **6-02.2.OPT48.GB6**, and **6-02.3(10)D.OPT3.GB6** for modifying bridge drains with modified concrete overlay projects. Include the above with **6-02.3(10)D.OPT4.GB6** for modifying bridge drains with waterproof membrane and

HMA overlay projects. Include with **6-02.3(10)D.OPT5.GB6** for plugging existing bridge drains. (2 fill-ins)

[6-02.5.OPT58.GB6](#)

(Core Drilled Bridge Deck Drain)

(April 6, 2015)

Use in projects where core drilled bridge deck drain is a stand-alone bid item. Include with **6-02.2.OPT58.GB6**, **6-02.3(10)D.OPT12.GB6**, and **6-02.4.OPT32.GB6**.

[6-02.5.OPT59.FB6](#)

(Core Drilled Bridge Deck Drain)

(April 6, 2015)

Use in projects where core drilled bridge deck drain is included in a separate bid item. The fill-in specifies the bid item including this work. Include with **6-02.2.OPT58.GB6** and **6-02.3(10)D.OPT12.GB6**. (1 fill-in)

[6-02.5.OPT71.GB6](#)

(Longitudinal Seismic Restrainer)

(April 6, 2015)

Use in projects where longitudinal seismic restrainer is a stand-alone bid item. Include with **6-02.2.OPT60(B).GB6**, **6-02.2.OPT60(C).GB6**, **6-02.2.OPT60(D).GB6**, **6-02.3.OPT8(L).GB6**, **6-02.4.OPT43.GB6** and all applicable seismic retrofit GSPs supplementing Sections 6-02.2 and 6-02.3.

[6-02.5.OPT72.GB6](#)

(Seismic Retrofit)

(April 6, 2015)

Use in projects with seismic retrofit of bridges. Include with **6-02.4.OPT44.FB6** and all applicable seismic retrofit GSPs supplementing Sections 6-02.2 and 6-02.3.

[6-02.5.OPT73.GB6](#)

(Column Jacketing)

(April 6, 2015)

Use in projects with column jacketing of bridges. Include with **6-02.2.OPT60(F).GB6**, **6-02.3.OPT8(C).GB6**, **6-02.3.OPT8(D).GB6**, **6-02.3.OPT8(E).GB6**, **6-02.3.OPT8(M).GB6**, **6-02.4.OPT45.FB6**, and **6-03.3(30).OPT1.FB6**. Include with **6-02.3.OPT8(F).FB6** when the pre-fabrication field measuring requirements for specific existing bridge columns are waived.

[6-02.5.OPT91.FB6](#)

(Bridge and Structures Minor Items)

(June 26, 2000)

Use in projects with bridges and other structures when there are minor items that are incidental to a lump sum or a unit price bid item. The first fill-in specifies the minor items. The second fill-in specifies the appropriate pay item(s) for the minor items. (2 fill-ins)

[6-02.5.OPT92.FB6](#)

(Bridge Supported Utilities)

(June 26, 2000)  
Use in projects requiring installation of bridge supported utilities. The first fill-in specifies the type of utility. The second fill-in specifies the bridge(s). The third fill-in specifies the work performed by the Contractor (furnishing materials, installing materials, coordination with utility, etc.), excluding furnishing and installing inserts. The fourth fill-in specifies the pay item. Include with **6-02.3.OPT2(B).GB6**, with appropriate bridge supported utility material GSP's, if all materials and work are supplied and performed by the Contractor. Include with **6-02.3.OPT2(C).GB6** and **6-02.5.OPT93.GB6** if a utility company is supplying and performing a portion of the utility materials and work. Include with **6-02.2.OPT46(A).GB6**, **6-02.3.OPT2(A).GB6**, **6-02.4.OPT1.FB6**, and **6-02.5.OPT26.FB6** when the supports include concrete inserts.  
(4 fill-ins)

[6-02.5.OPT93.GB6](#)

(Bridge Supported Utilities)  
(June 26, 2000)  
Use in projects requiring installation of bridge supported utilities where a utility company is supplying and performing a portion of the utility materials and work. Include with **6-02.3.OPT2(C).GB6** and **6-02.5.OPT92.FB6**, and appropriate bridge supported utility material GSP's. Include with **6-02.2.OPT46(A).GB6**, **6-02.3.OPT2(A).GB6**, **6-02.4.OPT1.FB6**, and **6-02.5.OPT26.FB6** when the supports include concrete inserts.

[6-03.GR6](#)

**Steel Structures**

[6-03.3.GR6](#)

**Construction Requirements**

[6-03.3\(7\).GR6](#)

**Shop Plans**

[6-03.3\(7\)A.GR6](#)

**Erection Methods**

[6-03.3\(7\)A.INST1.GR6](#) (The list in the second paragraph of Section 6-03.3(7)A is supplemented with the following)  
Must use once preceding any of the following:

[6-03.3\(7\)A.OPT1.GB6](#)

(Erection by Girder Launching)  
(April 6, 2015)  
Use in projects where girder launching may be used as an erection method.

[6-03.3\(7\)A.OPT2.GB6](#)

(Hand-held Drilling and Reaming)  
(April 6, 2015)  
Use in projects where drilling and reaming operations with hand-held devices is permissible. Include with **6-03.3(27)B.OPT1.FB6**.  
(1 fill-in)

**6-03.3(25).GR6**

**Welding and Repair Welding**

**6-03.3(25).INST1.GR6** (Section 6-03.3(25) is supplemented with the following)  
Must use once preceding any of the following:

**6-03.3(25).OPT2.GB6** (Narrow Gap Improved-Electroslag Welding  
(NGI-ESW) Procedure)  
(April 6, 2015)  
Use in projects with steel plate girder bridges and box  
girder bridges primarily with Grades 50 and 50W steel.  
Accompanying details are required in the Plans for  
NGI-ESW test joint configurations for WPS  
qualification and charpy v-notch test specimens.

**6-03.3(27).GR6**

**High Strength Bolt Holes**

**6-03.3(27)B.GR6**

**Reamed and Drilled Holes**

**6-03.3(27)B.INST1.GR6** (The second sentence of the first paragraph of Section  
6-03.3(27)B is revised to read)  
Must use once preceding any of the following:

**6-03.3(27)B.OPT1.FB6** (Hand-held Drilling and Reaming)  
(September 8, 2020)  
Use in projects where drilling and reaming  
operations with hand-held devices is permissible.  
The first fill-in specifies the members and items  
being drilled and reamed, and the second fill-in  
specifies the bridge(s) where the work is being  
done. Include with **6-03.3(7)A.OPT2.GB6**.  
(2 fill-ins)

**6-03.3(28).GR6**

**Shop Assembly**

**6-03.3(28)A.GR6**

**Method of Shop Assembly**

**6-03.3(28)A.INST1.GR6** (Section 6-03.3(28)A is supplemented with the  
following)  
Must use once preceding any of the following:

**6-03.3(28)A.OPT1.GB6** (Progressive Transverse Shop Assembly)  
(August 5, 2013)  
Use in projects with new steel girder bridges that  
have curved or skewed geometry, with the  
concurrence of the Bridge and Structures Office  
Steel Specialist. Include with **6-  
03.3(28)B.OPT1.GB6, 6-03.3(30).OPT1.FB6, 6-  
03.3(39).OPT1.GB6, 6-03.4.OPT1.FB6, and 6-  
03.5.OPT1.GB6**.

**6-03.3(28)B.GR6**

**Check of Shop Assembly**

6-03.3(28)B.INST1.GR6 (Section 6-03.3(28)B is supplemented with the following)  
Must use once preceding any of the following:

6-03.3(28)B.OPT1.GB6 (Check of Shop Assembly)  
(August 3, 2015)  
Use in projects with new steel bridges. Include with **6-03.3(30).OPT1.FB6**, **6-03.3(39).OPT1.GB6**, **6-03.4.OPT1.FB6**, and **6-03.5.OPT1.GB6**.

## 6-03.3(30).GR6                      **Painting**

6-03.3(30).INST1.GR6 (Section 6-03.3(30) is supplemented with the following)  
Must use once preceding any of the following:

6-03.3(30).OPT1.FB6 (Color of Finish Coat)  
(August 3, 2009)  
Use in projects with new steel bridges and steel members to cover paint color requirements by specifying the SAE AMS Standard 595 Color Number, or the color name if no number. Include with **6-03.3(28)B.OPT1.GB6**, **6-03.3(39).OPT1.GB6**, **6-03.4.OPT1.FB6**, and **6-03.5.OPT1.GB6**.

Also include in projects with new minor steel items such as steel expansion joints (**6-02.3(13).OPT3.FB6**, **6-02.4.OPT3.FB6**, **6-02.5.OPT28.GB6**, and **6-02.2.OPT22.GB6**) and bearings (**6-02.3(19)B.OPT1.GB6**).  
(1 fill-in)

6-03.3(30).OPT6.FB6 (Painting Galvanized Seismic Retrofit Components)  
(April 6, 2015)  
Use in seismic retrofit projects where galvanized steel components are attached to painted members of existing steel bridges to cover paint color requirements. The first fill-in specifies the galvanized components to be painted. The second fill-in specifies the SAE AMS Standard 595 Color Number, or the color name if no number.  
(2 fill-ins)

## 6-03.3(38).GR6                      **Placing Superstructure**

6-03.3(38).INST1.GR6 (Section 6-03.3(38) is supplemented with the following)  
Must use once preceding any of the following:

6-03.3(38).OPT1.GB6 (Concrete Protection)  
(August 3, 2015)  
Use within projects with bridges having weathering steel superstructure members which remain unpainted at completion of construction, and which are above

concrete surfaces which require protection from staining while the steel members develop their weathered protective surface. Include with **6-03.5.OPT7.FB6**.

**6-03.3(39).GR6**

**Swinging the Span**

**6-03.3(39).INST1.GR6** (Section 6-03.3(39) is supplemented with the following)  
Must use once preceding any of the following:

**6-03.3(39).OPT1.GB6** (Girder Camber Field Measurements)  
(June 26, 2000)  
Use in projects with new steel bridges. Include with **6-03.3(28)B.OPT1.GB6**, **6-03.3(30).OPT1.FB6**, **6-03.4.OPT1.FB6**, and **6-03.5.OPT1.GB6**.

**6-03.4.GR6**

**Measurement**

**6-03.4.INST1.GR6** (Section 6-03.4 is supplemented with the following)  
Must use once preceding any of the following:

**6-03.4.OPT1.FB6** (Structural Low Alloy Quantities)  
(August 6, 2007)  
Use in projects with new steel bridges. Include with **6-03.3(28)B.OPT1.GB6**, **6-03.3(30).OPT1.FB6**, and **6-03.3(39).OPT1.GB6**. Include with **6-03.5.OPT1.GB6** when the steel girder includes a pipe railing.  
(2 fill-ins)

**6-03.5.GR6**

**Payment**

**6-03.5.INST1.GR6** (The second bid item under Section 6-03.5 is supplemented with the following)  
Must use once preceding any of the following:

**6-03.5.OPT1.GB6** (Payment for Steel Girder Railing)  
(August 6, 2007)  
Use in projects with new steel bridges when the steel girder includes a pipe railing. Include with **6-03.3(28)B.OPT1.GB6**, **6-03.3(30).OPT1.FB6**, **6-03.3(39).OPT1.GB6**, and **6-03.4.OPT1.FB6**.

**6-03.5.INST2.GR6** (Section 6-03.5 is supplemented with the following)  
Must use once preceding any of the following:

**6-03.5.OPT7.FB6** (Payment for Concrete Protection)  
(June 26, 2000)  
Use in projects with bridges having weathering steel members which remain unpainted at the completion of construction, and which are above concrete surfaces which require protection from staining while the steel members develop their weathered protective surface. Include with **6-03.3(38).OPT1.GB6**.

(1 fill-in)

## **6-04.GR6**

### **Timber Structures**

#### **6-04.3.GR6**

#### **Construction Requirements**

##### **6-04.3(1).GR6**

##### **Storing and Handling Material**

###### **6-04.3(1).INST1.GR6**

(Section 6-04.3(1) is supplemented with the following)  
Must use once preceding any of the following:

###### **6-04.3(1).OPT1.GB6**

(Fire Prevention)  
(March 6, 2000)  
Use in all timber bridge construction and timber deck replacement projects. Include with **6-04.5.OPT1.FB6**.

###### **6-04.3(1).OPT2.GB6**

(Top Flange Treatment)  
(January 2, 2018)  
Include in timber redecking projects. Include with **6-04.3(1).OPT1.GB6**, **6-04.5.OPT1.FB6**, and **6-04.5.OPT2.FB6**.

#### **6-04.5.GR6**

#### **Payment**

###### **6-04.5.INST1.GR6**

(Section 6-04.5 is supplemented with the following)  
Must use once preceding any of the following:

###### **6-04.5.OPT1.FB6**

(Fire Protection)  
(March 6, 2000)  
Use in all timber bridge construction and timber deck replacement projects. Include with **6-04.3(1).OPT1.GB6**.  
(1 fill-in)

###### **6-04.5.OPT2.FB6**

(Top Flange Treatment)  
(March 6, 2000)  
Use in timber deck replacement projects. Include with **6-04.3(1).OPT1.GB6**, **6-04.3(1).OPT2.GB6**, and **6-04.5.OPT1.FB6**.  
(1 fill-in)

## **6-05.GR6**

### **Piling**

#### **6-05.2.GR6**

#### **Materials**

###### **6-05.2.INST1.GR6**

(Section 6-05.2 is supplemented with the following)  
Must use once preceding any of the following:

###### **6-05.2.OPT1.GB6**

Micropiles  
(April 6, 2015)  
Use in projects where micropiles are required. Include with **6-05.3.OPT1.FB6**, **6-05.4.OPT6.GB6**, and **6-05.5.OPT6.GB6**.

#### **6-05.3.GR6**

#### **Construction Requirements**

[6-05.3.INST1.GR6](#)

(Section 6-05.3 is supplemented with the following)  
Must use once preceding any of the following:

[6-05.3.OPT1.FB6](#)

Micropiles  
(October 3, 2022)  
Use in projects where micropiles are required. The first fill-in specifies the top elevation of the micropile bond zone. The second fill-in specifies the location(s) of micropile verification tests. The third fill in is the 1.00 FDL deflection limit for the verification load test. The fourth fill in is the 1.00 FDL deflection limit for the proof load test. Include with **6-05.2.OPT1.FB6**, **6-05.4.OPT6.GB6**, and **6-05.5.OPT6.GB6**.  
(Four fill-ins)

[6-05.3\(5\).GR6](#)

**Manufacture of Steel Piles**

[6-05.3\(5\).INST1.GR6](#)

(Section 6-05.3(5) is supplemented with the following)  
Must use once preceding any of the following:

[6-05.3\(5\).OPT1.GB6](#)

(Furnishing St. Piling)  
(September 8, 2020)  
Use in projects with steel piling where the piling consists of hollow steel pipe that may or may not be filled with concrete and steel reinforcing bars for a portion of its length. Include with **6-05.3(6).OPT1.GB6**

[6-05.3\(6\).GR6](#)

**Splicing Steel Casings and Steel Piles**

[6-05.3\(6\).INST1.GR6](#)

(Section 6-05.3(6) is supplemented with the following)  
Must use once preceding any of the following:

[6-05.3\(6\).OPT1.GB6](#)

(Furnishing St. Piling)  
(September 8, 2020)  
Use in projects with steel piling where the piling consists of hollow steel pipe that may or may not be filled with concrete and steel reinforcing bars for a portion of its length. Include with **6-05.3(5).OPT1.GB6**.

[6-05.3\(10\).GR6](#)

**Test Piles**

[6-05.3\(10\).INST1.GR6](#)

(Section 6-05.3(10) is supplemented with the following)  
Must use once preceding any of the following:

[6-05.3\(10\).OPT1.FB6](#)

(Furnishing and Driving Test Piles)  
(March 6, 2000)  
Include in projects having test piles, as recommended by the State Geotechnical Office. The first, third, and fourth fill-ins specify the pile type (cast-in-place conc.,

1 steel, timber, etc.). The second fill-in specifies the  
2 general location (bridge and pier).  
3 (4 fill-ins)  
4

5 **6-05.3(11).GR6**

5 **Driving Piles**

6  
7 **6-05.3(11)D.GR6**

7 **Achieving Minimum Tip Elevation and**  
8 **Bearing**

9  
10 **6-05.3(11)D.INST1.GR6** (Section 6-05.3(11)D is supplemented with  
11 the following)  
12 Must use once preceding any of the following:

13  
14 **6-05.3(11)D.OPT2.GB6** (Vibration From Pile Driving)  
15 (August 3, 2015)  
16 Include in projects where minimizing vibration  
17 from driving piles is critical, as recommended by  
18 the State Geotechnical Office.  
19

20 **6-05.3(11)D.OPT3.FB6** (Preboring Piles)  
21 (August 3, 2015)  
22 Include in projects where preboring of piles is  
23 required to prevent downdrag from settlement, as  
24 recommended by the State Geotechnical Office.  
25 The first fill-in specifies the pile type (cast-in-  
26 place conc., steel, timber, etc.). The second fill-in  
27 specifies the general location (bridge and pier).  
28 The third fill-in specifies the bottom elevation of  
29 the preboring. Include with **6-05.4.OPT1.FB6**  
30 **and 6-05.5.OPT1.FB6.**  
31 (3 fill-ins)  
32

33 **6-05.3(11)D.OPT4.FB6** (Preboring Piles)  
34 (August 3, 2015)  
35 Include in projects where preboring of piles is  
36 required, as recommended by the State  
37 Geotechnical Office. The first fill-in specifies the  
38 pile type (cast-in-place conc., steel, timber, etc.).  
39 The second fill-in specifies the general location  
40 (bridge and pier). The third fill-in specifies the  
41 bottom elevation of the preboring. Include with **6-**  
42 **05.4.OPT1.FB6 and 6-05.5.OPT1.FB6.**  
43 (3 fill-ins)  
44

45 **6-05.3(11)D.OPT9.FB6** (Overdriving)  
46 (April 6, 2015)  
47 Include in projects where overdriving of piles is  
48 anticipated in order to reach the minimum tip  
49 elevation, as recommended by the State  
50 Geotechnical Office. The first fill-in specifies the  
51 general location(s) (bridge and pier) of the  
52 anticipated pile overdriving. The second fill-in

specifies the approximate magnitude of expected  
overdriving.  
(2 fill-ins)

#### **6-05.4.GR6**

#### **Measurement**

##### **6-05.4.INST1.GR6**

(Section 6-05.4 is supplemented with the following)  
Must use once preceding any of the following:

##### **6-05.4.OPT1.FB6**

(Preboring Piles)  
(March 6, 2000)  
Use in projects where preboring of piles is required, as recommended by the State Geotechnical Office. The fill-in specifies the pile type (cast-in-place conc., steel, timber, etc.). Include with **6-05.3(11)D.OPT3.FB6 or 6-05.3(11)D.OPT4.FB6, and 6-05.5.OPT1.FB6.**  
(1 fill-in)

##### **6-05.4.OPT6.GB6**

Micropiles  
(April 6, 2015)  
Use in projects where micropiles are required. Include with **6-05.2.OPT1.FB6, 6-05.3.OPT1.FB6, and 6-05.5.OPT6.GB6.**

#### **6-05.5.GR6**

#### **Payment**

##### **6-05.5.INST1.GR6**

(Section 6-05.5 is supplemented with the following)  
Must use once preceding any of the following:

##### **6-05.5.OPT1.FB6**

(Preboring Piles)  
(March 6, 2000)  
Use in projects where preboring of piles is required, as recommended by the State Geotechnical Office. Both fill-ins specify the pile type (cast-in-place conc., steel, timber, etc.). Include with **6-05.3(11)D.OPT3.FB6 or 6-05.3(11)D.OPT4.FB6, and 6-05.4.OPT1.FB6.**  
(2 fill-ins)

##### **6-05.5.OPT6.GB6**

Micropiles  
(April 6, 2015)  
Use in projects where micropiles are required. Include with **6-05.2.OPT1.FB6, 6-05.3.OPT1.FB6, and 6-05.4.OPT6.GB6.**

#### **6-06.GR6**

#### **Bridge Railings**

#### **6-06.2.GR6**

#### **Materials**

##### **6-06.2.INST1.GR6**

(Section 6-06.2 is supplemented with the following)  
Must use once preceding any of the following:

##### **6-06.2.OPT1.GB6**

(Bridge Railing Type Chain Link Fence)  
(November 20, 2023)

Use in projects with Bridge Railing Type Chain Link Fence. Include with **6-06.3(2).OPT1.GB6**. Also include **6-06.5.OPT1.FB6** if the work is included as part of a separate bid item such as "Superstructure - \_\_\_\_", or "Roadway Deck - \_\_\_\_".

[6-06.2.OPT2.GB6](#)

(Bridge Railing Type Chain Link Fence)

(March 6, 2000)

Use in projects with Bridge Railing Type Chain Link Fence where the posts are set into blockouts with epoxy resin. Include with **6-06.2.OPT1.GB6 and 6-06.3(2).OPT2.GB6**. Also include **6-06.5.OPT1.FB6** if the work is included as part of a separate bid item such as "Superstructure - \_\_\_\_", or "Roadway Deck - \_\_\_\_".

[6-06.2.OPT7.GB6](#)

(Tamper Proof Nuts for steel Bridge Railing Type BP)

(April 6, 2015)

Use in projects where steel Bridge Railing Type BP is used.

[6-06.2.OPT8.FB6](#)

(Bridge Railing Type Snow Fence and Bridge Railing Type Wire Fabric Fence)

(November 20, 2023)

Use in projects with Bridge Railing Type Snow Fence or Bridge Railing Type Wire Fabric Fence. The fill-in specifies the Federal Standard 595 Color Number, or the color name if no number.

Include with **6-06.3(2).OPT7.GB6**.

(1 fill-in)

[6-06.3.GR6](#)

**Construction Requirements**

[6-06.3\(2\).GR6](#)

**Metal Railings**

[6-06.3\(2\).INST1.GR6](#)

(Section 6-06.3(2) is supplemented with the following)

Must use once preceding any of the following:

[6-06.3\(2\).OPT1.GB6](#)

(Bridge Railing Type Chain Link Fence)

(November 20, 2023)

Use in projects with Bridge Railing Type Chain Link Fence where the posts are fastened into position with anchor bolts or resin bonded anchors. Include with **6-06.2.OPT1.GB6**. Also include **6-06.5.OPT1.FB6** if the work is included as part of a separate bid item such as "Superstructure - \_\_\_\_", or "Roadway Deck - \_\_\_\_".

[6-06.3\(2\).OPT2.GB6](#)

(Bridge Railing Type Chain Link Fence)

(March 6, 2000)

Use in projects with Bridge Railing Type Chain Link Fence where the posts are set into blockouts with epoxy resin. Include with **6-06.2.OPT1.GB6 and 6-**

**06.2.OPT2.GB6.** Also include **6-06.5.OPT1.FB6** if the work is included as part of a separate bid item such as “Superstructure - \_\_\_\_”, or “Roadway Deck - \_\_\_\_”.

**6-06.3(2).OPT7.GB6**

(Bridge Railing Type Snow Fence and Bridge Railing Type Wire Fabric Fence)  
(November 20, 2023)  
Use in projects with Bridge Railing Type Snow Fence or Bridge Railing Type Wire Fabric Fence. Include with **6-06.2.OPT8.FB6**.

**6-06.5.GR6**

**Payment**

**6-06.5.INST1.GR6**

(Section 6-06.5 is supplemented with the following)  
Must use once preceding any of the following:

**6-06.5.OPT1.FB6**

(Bridge Railing)  
(March 6, 2000)  
Use in projects with bridge railing where the work is included as part of a separate bid item such as “Superstructure - \_\_\_\_”, or “Roadway Deck - \_\_\_\_”. The first fill-in specifies the bridge railing type. The second fill-in specifies the bid item name.  
(2 fill-ins)

**6-07.GR6**

**Painting**

**6-07.1.GR6**

**Description**

**6-07.1.INST1.GR6**

(Section 6-07.1 is supplemented with the following)  
Must use once preceding any of the following:

**6-07.1.OPT1.FB6**

(Scope of Work)  
(August 3, 2009)  
Include in projects with cleaning and painting of existing steel bridge(s). Use to define limits of cleaning and painting by using the second fill-in to specify surfaces that are not to be painted (light fixtures, utilities, bridge attachments, etc.). Include with **6-07.3(10)D.OPT1.FB6 and/or 6-07.3(10)E.OPT1.FB6** as appropriate for the surface preparation requirements. Include with **DESWORK2.FB1 and 6-07.3(10)I.OPT1.FB6**. Include with **1-07.1(2).OPT3.FR1** if the existing bridge(s) contain lead paint. Include with **1-07.6.OPT4.GB1** if the bridge(s) cross a navigable waterway.  
(2 fill-ins)

**6-07.1.OPT2.FB6**

(Scope of Work)  
(August 3, 2009)  
Include in projects with cleaning and painting of existing timber bridge(s). Use to define limits of cleaning and painting by using the second fill-in to specify the surfaces to be painted (railing, rail posts, wheelguards, etc.).

1 Include with **1-07.1(2).OPT3.FR1** if the existing bridge(s)  
2 contain lead paint. Project specific Special Provisions  
3 supplementing Section 6-07.3(13) may be required to  
4 specify specific primer and top coat paint requirements.  
5 (2 fill-ins)  
6

7 **6-07.3.GR6**

8 **Construction Requirements**

9 **6-07.3(10).GR6**

10 **Painting Existing Steel Structures**

11 **6-07.3(10).INST1.GR6**

12 (Section 6-07.3(10) is supplemented with the  
13 following)

14 Must use once preceding any of the following:

15 **6-07.3(10).OPT1.FB6**

16 (Utility Conduits)  
17 (August 3, 2009)

18 Include only when utility conduits are attached to the  
19 existing bridge(s) being painted. Fill-in to read "shall or  
20 "shall not". Include with **DESWORK2.FB1, 6-  
21 07.1.OPT1.FB6 and 6-07.3(10).I.OPT1.FB6.**  
22 (1 fill-in)

23 **6-07.3(10).OPT2.GB6**

24 (Light Fixtures)  
25 (August 3, 2009)

26 Include only when light fixtures are attached to existing  
27 bridge(s) being painted. Include with  
28 **DESWORK2.FB1, 6-07.1.OPT1.FB6 and 6-  
29 07.3(10).I.OPT1.FB6.**

30 **6-07.3(10).OPT4.GB6**

31 (Cleaning Grid Deck)  
32 (August 3, 2015)

33 Use with **DESWORK2.FB1, 6-07.1.OPT1.FB6, 6-  
34 07.3(10).I.OPT1.FB6, and 6-07.3(10).N.OPT1.GB6** if  
35 the bridge has a grid roadway deck or steel grid  
36 catwalks which require cleaning and painting.

37 **6-07.3(10).A.GR6**

38 **Containment**

39 **6-07.3(10).A.INST1.GR6**

40 (Section 6-07.3(10)A is supplemented with  
41 the following)

42 Must use once preceding any of the following:

43 **6-07.3(10).A.OPT1.GB6**

44 (Protection of Existing Structure)  
45 (August 3, 2009)

46 Use only when the bridge has mechanical  
47 equipment to protect such as a draw bridge.  
48 Include with **DESWORK2.FB1, 6-  
49 07.1.OPT1.FB6 and 6-07.3(10).I.OPT1.FB6.**

50 **6-07.3(10).A.OPT2.FB6**

51 (Containment System)  
(September 7, 2021)

1 Use when a paint removal containment system  
2 must be removed from a bridge when winds at  
3 the site exceed a wind speed/gust threshold.  
4 Fill-in #1 specifies the bridge(s) that have wind  
5 speed/gust thresholds.  
6 Fill-in #2 specifies the wind speed/gust threshold.  
7 (2 fill-ins)

8  
9 **6-07.3(10)D.GR6**

**Surface Preparation Prior to Overcoat Painting**

10  
11 **6-07.3(10)D.INST1.GR6** (Section 6-07.3(10)D is supplemented with  
12 the following)  
13 Must use once preceding any of the following:

14  
15 **6-07.3(10)D.OPT1.FB6** (Surfaces Requiring Overcoat Painting  
16 Surface Preparation)  
17 (April 6, 2015)  
18 Use in bridge painting projects with bridges and  
19 bridge members requiring surface preparation for  
20 overcoat painting. Include with  
21 **DESWORK2.FB1, 1-07.6.OPT3(A).FB1, 6-**  
22 **07.1.OPT1.FB6 and 6-07.3(10)I.OPT1.FB6.**  
23 Include with **6-07.3(10)E.OPT1.FB6** if the  
24 bridge(s) also have bridge members requiring full  
25 paint removal. Include with **1-07.1(2).OPT3.FR1**  
26 if the existing bridge(s) contain lead paint. The  
27 first fill-in specifies the bridge(s) requiring  
28 overcoat painting surface preparation. The  
29 second fill-in specifies the bridge members  
30 requiring overcoat painting surface preparation.  
31 (2 fill-ins)

32  
33 **6-07.3(10)E.GR6**

**Surface Preparation – Full Paint Removal**

34  
35 **6-07.3(10)E.INST1.GR6** (Section 6-07.3(10)E is supplemented with  
36 the following)  
37 Use once preceding any of the following:

38  
39 **6-07.3(10)E.OPT1.FB6** (Surfaces Requiring Full Paint Removal  
40 Surface)  
41 Preparation)  
42 (April 5, 2010)  
43 Use in bridge painting projects with bridges and  
44 bridge members requiring surface preparation for  
45 full paint removal. Include with  
46 **DESWORK2.FB1, 1-07.6.OPT3(A).FB1, 6-**  
47 **07.1.OPT1.FB6 and 6-07.3(10)I.OPT1.FB6.**  
48 Include with **6-07.3(10)D.OPT1.FB6** if the  
49 bridge(s) also have bridge members requiring  
50 overcoat painting. Include with **1-**  
51 **07.1(2).OPT3.FR1** if the existing bridge(s)  
52 contain lead paint. The first fill-in specifies the  
53 bridge(s) requiring full paint removal surface

preparation. The second fill-in specifies the bridge members requiring full paint removal surface preparation.  
(2 fill-ins)

#### **6-07.3(10)I.GR6**

#### **Paint Color**

6-07.3(10)I.INST1.GR6 (Section 6-07.3(10)I is supplemented with the following)

Must use once preceding any of the following:

#### **6-07.3(10)I.OPT1.FB6**

(Color of Top Coat)

(August 3, 2009)

Use in projects with existing steel bridges and bridge members to cover paint color requirements by specifying the SAE AMS Standard 595 Color Number, or the color name if no number. Use with **DESWORK2.FB1**, **1-07.6.OPT3(A).FB1**, and **6-07.1.OPT1.FB6**. Include with **6-07.3(10)D.OPT1.FB6** and/or **6-07.3(10)E.OPT1.FB6** as appropriate for the surface preparation requirements. Include with **1-07.1(2).OPT3.FR1** if the existing bridge(s) contain lead paint.  
(1 fill-in)

#### **6-07.3(10)N.GR6**

#### **Field Coating Application Methods**

6-07.3(10)N.INST1.GR6 (Section 6-07.3(10)N is supplemented with the following)

Must use once preceding any of the following:

#### **6-07.3(10)N.OPT1.GB6**

(Painting Grid Deck)

(August 3, 2009)

Use with **DESWORK2.FB1**, **6-07.1.OPT1.FB6**, **6-07.3(10).OPT4.GB6** and **6-07.3(10)I.OPT1.FB6** if the bridge has a grid roadway deck or steel grid catwalks which require painting.

#### **6-07.3(11).GR6**

#### **Painting or Powder Coating of Galvanized Surfaces**

6-07.3(11).INST1.GR6 (Section 6-07.3(11) is supplemented with the following)

Must use once preceding any of the following:

#### **6-07.3(11).OPT1.FB6**

(Coating Color)

(August 3, 2009)

Use in projects requiring coating of galvanized surfaces with either paint or powder coating. The fill-in specifies the SAE AMS Standard 595 color number, or the color name if no number.  
(1 fill-in)

**6-08.GR6**

**Bituminous Surfacing on Structure Decks**

**6-08.3.GR6**

**Construction Requirements**

**6-08.3.INST1.GR6**

(Section 6-08.3 is supplemented with the following)  
Must use once preceding the following:

**6-08.3.OPT1.FB6**

(Surfacing Removal and Paving Equipment Load and Spacing Restrictions)  
(October 29, 2020)  
Use in bridge deck paving projects where specific bridges are subject to surfacing removal and paving equipment load and spacing restrictions as shown and specified in the Plans. The fill-in specifies the Bridge Number(s) of the bridge(s) affected by these restrictions.  
(1-fill-in)

**6-08.3(2).GR6**

**Contractor Survey for Grade-Controlled Structure Decks**

**6-08.3(2).INST1.GR6**

(Section 6-08.3(2) is supplemented with the following)  
Must use once preceding any of the following:

**6-08.3(2).OPT1.FB6**

(Contractor Structure Survey Not Applicable)  
(January 3, 2017)  
Use in projects where the Contracting Agency performs the Structure survey for Grade Controlled Structure Decks, and the Contract Plans were adjusted for Final Grade Profile and Adjusted Removal Depth as needed. The fill-in specifies the Bridge number(s) where the Contracting Agency is performing the survey.  
(1 fill-in)

**6-08.3(5).GR6**

**Full Depth Removal of Bituminous Pavement from Bridge Decks**

**6-08.3(5).INST1.GR6**

(Section 6-08.3(5) is supplemented with the following)  
Must use once preceding any of the following:

**6-08.3(5).OPT1.FB6**

(Rotary milling/planing equipment prohibited)  
(January 2, 2018)  
Use in bridge deck paving projects where equipment used to perform full depth removal of existing surfacing from specific Grade Controlled bridges is restricted to exclude rotary milling/planing equipment. Bridges in this category are generally identified in the Bridge Condition Report (BCR) prepared for the project by the Bridge Asset Management unit of the Bridge and Structures Office and provided to the Region Design PE Offices as part of the site data at the beginning of

the project design phase. The fill-in specifies the Bridge Number(s) of the bridges affected by these restrictions.

(1 fill-in)

[6-08.3\(5\).OPT2.FB6](#)

(Rotary milling/planing equipment restricted to upper layer of existing surfacing)

(January 2, 2018)

Use in bridge deck paving projects where equipment used to perform full depth removal of existing surfacing from specific Grade Controlled bridges is restricted to allow rotary milling/planing equipment for the upper layer 0.10-feet above the bridge deck. Existing surfacing thicknesses at these bridges shall be 0.20-feet minimum. The fill-in specifies the Bridge Number(s) of the bridges affected by these restrictions. (1 fill-in)

[6-10.GR6](#)

**Concrete Barrier**

[6-10.3.GR6](#)

**Construction Requirements**

[6-10.3\(5\).GR6](#)

**Temporary Barrier**

[6-10.3\(5\).INST1.GR6](#)

(The first paragraph of Section 6-10.3(5) is revised to read)

Must use once preceding any of the following:

[6-10.3\(5\).OPT1.GR6](#)

(Type F Temporary Barrier)

(February 3, 2020)

Use in projects that have less than 1,000 linear feet of temporary barrier. The use of this GSP on projects with more than 1,000 linear feet of temporary barrier requires approval from HQ Construction.

Do not use with **6-10.3(5).OPT2.2025.GR6**.

[6-10.5.GR6](#)

**Payment**

[6-10.5.INST1.GR6](#)

(Section 6-10.5 is supplemented with the following)

Must use once preceding any of the following:

[6-10.5.OPT1.GR6](#)

(Temporary barrier delineators)

(August 1, 2016)

Use in projects that require temporary barrier to be placed adjacent to a travelled lane.

[6-10.5.OPT2.FB6](#)

(Bridge Concrete Barrier)

(March 6, 2000)

Use in projects with concrete barrier on bridges only where the barrier is included as part of a separate bid item such as "Superstructure - \_\_\_\_", or "Roadway Deck - \_\_\_\_". The first fill-in specifies the barrier type (traffic barrier,

1 traffic-pedestrian barrier, pedestrian barrier, etc.). The  
2 second fill-in specifies the bid item name.  
3 (2 fill-ins)  
4

5 **6-12.GR6**

6 **Noise Barrier Walls**

7 **6-12.2.GR6**

8 **Materials**

9 **6-12.2.INST1.GR6**

10 (Section 6-12.2 is supplemented with the following)  
11 Must use once preceding any of the following:

12 **6-12.2.OPT1.GB6**

13 (Precast Concrete Noise Barrier Walls)  
14 (September 8, 2020)  
15 Use in projects with noise barrier walls of precast concrete  
16 panels. Include with **6-12.3(6).OPT1.FB6 and all other**  
17 ***applicable noise barrier wall GSP's.***

18 **6-12.2.OPT2.FB6**

19 (Masonry Noise Barrier Walls)  
20 (September 8, 2020)  
21 Use in projects with noise barrier walls of masonry block  
22 panels. The fill-in describes the surface texture and color  
23 requirements for the field, cap, accent, and other CMU  
24 blocks used for the masonry wall. Include with **6-**  
25 **12.3(7).OPT1.GB6 and all other applicable noise**  
26 ***barrier wall GSP's.***  
27 (1 fill-in)

28 **6-12.3.GR6**

29 **Construction Requirements**

30 **6-12.3(1).GR6**

31 **Submittals**

32 **6-12.3(1).INST1.GR6**

33 (Section 6-12.3(1) is supplemented with the  
34 following)  
35 Must use once preceding any of the following:

36 **6-12.3(1).OPT1.GB6**

37 (Noise Barrier Wall Existing Groundline Field  
38 Survey)  
39 (August 3, 2015)  
40 Use in noise barrier wall projects where the Contractor  
41 is required to perform and submit a field survey of the  
42 existing noise barrier wall alignment. Include with **1-**  
43 **05.4.OPT1.GR1, 6-12.5.OPT1.GB6, and all other**  
44 ***applicable noise barrier wall GSP's.***

45 **6-12.3(6).GR6**

46 **Precast Concrete Panel Fabrication and Erection**

47 **6-12.3(6).INST1.GR6**

48 (Section 6-12.3(6) is supplemented with the  
49 following)  
50 Must use once preceding any of the following:

51 **6-12.3(6).OPT1.FB6**

52 (Precast Concrete Panel Surface  
53 Finish Requirements)  
(April 5, 2004)

1 Use in projects with noise barrier walls of precast  
2 concrete panels. The fill-ins specify the type or name  
3 of the formed finish on the traffic side and on the  
4 residential side of the precast concrete panels. Include  
5 with **6-12.2.OPT1.GB6 and all other applicable**  
6 **noise barrier wall GSP's.**  
7 (2 fill-ins)  
8

9 **6-12.3(7).GR6**

**Masonry Wall Construction**

10 **6-12.3(7).INST1.GR6**

(Section 6-12.3(7) is supplemented with the  
following)

Must use once preceding any of the following:

14 **6-12.3(7).OPT1.GB6**

(Masonry Noise Barrier Wall  
Construction Requirements)  
(August 3, 2015)

Use in projects with noise barrier walls of masonry  
block panels. Include with **6-12.2.OPT2.FB6 and all**  
**other applicable noise barrier wall GSP's.**

21 **6-12.5.GR6**

**Payment**

23 **6-12.5.INST1.GR6**

(Section 6-12.5 is supplemented with the following)  
Must use once preceding any of the following:

26 **6-12.5.OPT1.GB6**

(Payment for Noise Barrier Wall Groundline Field  
Survey)  
(April 5, 2004)

Use in noise barrier wall projects where the Contractor is  
required to perform and submit a field survey of the  
existing noise barrier wall alignment. Include with **1-**  
**05.4.OPT1.GR1, 6-12.3(1).OPT1.GB6, and all other**  
**applicable noise barrier wall GSP's.**

35 **6-13.GR6**

**Structural Earth Walls**

37 **6-13.2.GR6**

**Materials**

39 **6-13.2.INST1.GR6**

(Section 6-13.2 is supplemented with the following)  
Must use once preceding any of the following:

42 **6-13.2.OPT1.GB6**

(Welded Wire Faced Structural Earth Wall  
Materials)  
(February 6, 2023)

Use in projects with structural earth walls where welded  
wire faced walls are an acceptable alternative. Include  
with **6-13.3.OPT1.GB6 and 6-13.3(2).OPT1.FB6.**

49 **6-13.2.OPT2.GB6**

(Precast Concrete Panel Faced  
Structural Earth Wall Materials)  
(February 6, 2023)

Use in projects with structural earth walls where precast concrete panel faced walls are an acceptable alternative. Include with **6-13.3.OPT2.GB6, 6-13.3(2).OPT1.FB6, 6-13.3(4).OPT1.GB6.**

**6-13.2.OPT2(A).GB6**

(Lock + Load Retaining Wall System Wall Materials)  
(August 3, 2015)

Use in projects with structural earth walls only when the following conditions apply:

1. Both precast concrete panel faced structural earth walls AND precast concrete block faced structural earth walls are included in the project as acceptable alternatives.
2. Lock + Load retaining wall system shall be constructed in areas where the wall will be constructed above the water table.

Include with **6-13.2.OPT2.GB6, 6-13.3.OPT2.GB6, 6-13.3(2).OPT1.FB6, 6-13.3.OPT2(A).GB6, 6-13.3(4).OPT1.GB6, 6-13.3(4).OPT1(A).GB6, and 6-13.3(7).OPT1.GB6.**

**6-13.2.OPT3.GB6**

(Concrete Block Faced Structural Earth Wall Materials)

(January 2, 2018)

Use in projects with structural earth walls where concrete block faced walls are an acceptable alternative. Include with **6-13.3.OPT3.GB6, 6-13.3(2).OPT1.FB6, and 6-13.3(5).OPT2.GB6.**

**6-13.3.GR6**

**Construction Requirements**

**6-13.3.INST1.GR6**

(Section 6-13.3 is supplemented with the following)  
Must use once preceding any of the following:

**6-13.3.OPT1.GB6**

(Welded Wire Faced Structural Earth Wall)  
(April 4, 2011)

Use in projects with structural earth walls where welded wire faced walls are an acceptable alternative. Include with **6-13.2.OPT1.GB6 and 6-13.3(2).OPT1.FB6.**

**6-13.3.OPT2.GB6**

(Precast Concrete Panel Faced Structural Earth Wall)

(January 10, 2022)

Use in projects with structural earth walls where precast concrete panel faced walls are an acceptable alternative. Include with **6-13.2.OPT2.GB6, 6-13.3(2).OPT1.FB6, and 6-13.3(4).OPT1.GB6.**

**6-13.3.OPT2(A).GB6**

(Lock + Load Retaining Wall System Walls)  
(August 3, 2015)

Use in projects with structural earth walls only when the following conditions apply:

1. Both precast concrete panel faced structural earth walls AND precast concrete block faced structural earth walls are included in the project as acceptable alternatives.
2. Lock + Load retaining wall system shall be constructed in areas where the wall will be constructed above the water table.

Include with **6-13.2.OPT2.GB6, 6-13.2.OPT2(A).GB6, 6-13.3.OPT2.GB6, 6-13.3(2).OPT1.FB6, 6-13.3(4).OPT1.GB6, 6-13.3(4).OPT1(A).GB6, and 6-13.3(7).OPT1.GB6.**

#### 6-13.3.OPT3.GB6

(Concrete Block Faced Structural Earth Wall)  
(January 2, 2018)

Use in projects with structural earth walls where concrete block faced walls are an acceptable alternative. Include with **6-13.2.OPT3.GB6, 6-13.3(2).OPT1.FB6, and 6-13.3(5).OPT2.GB6.**

#### 6-13.3(2).GR6

##### **Submittals**

#### 6-13.3(2).INST1.GR6

(Section 6-13.3(2) is supplemented with the following)

Must use once preceding any of the following:

#### 6-13.3(2).OPT1.FB6

(Structural Earth Wall Geotechnical Design Parameters)

(January 3, 2011)

Use in projects with structural earth walls. The first fill-in identifies the wall by name or number, and the remaining fill-ins specify the values for various geotechnical design parameters as specified in the geotechnical report prepared for the project. The table may be repeated as necessary for additional walls with differing geotechnical design parameters.  
(13 fill-ins)

#### 6-13.3(4).GR6

##### **Precast Concrete Facing Panel and Concrete Block Fabrication**

#### 6-13.3(4).INST1.GR6

(Section 6-13.3(4) is supplemented with the following)

Must use once preceding any of the following:

#### 6-13.3(4).OPT1.GB6

(Specific Fabrication Requirements for Precast Concrete Panel Faced Structural Earth Walls)  
(April 3, 2017)

Use in projects with structural earth walls where precast concrete panel faced walls are an acceptable alternative. Include with **6-13.2.OPT2.GB6, 6-13.3.OPT2.GB6, 6-13.3(2).OPT1.FB6, and 6-13.3(5).OPT1.GB6.**

**6-13.3(4).OPT1(A).GB6**

(Lock + Load Retaining Wall System Walls)

(August 3, 2015)

Use in projects with structural earth walls only when the following conditions apply:

1. Both precast concrete panel faced structural earth walls AND precast concrete block faced structural earth walls are included in the project as acceptable alternatives.

2. Lock + Load retaining wall system shall be constructed in areas where the wall will be constructed above the water table.

Include with **6-13.2.OPT2.GB6, 6-13.2.OPT2(A).GB6, 6-13.3.OPT2.GB6, 6-13.3.OPT2(A).GB6, 6-13.3(2).OPT1.FB6, 6-13.3(4).OPT1.GB6, and 6-13.3(7).OPT1.GB6.**

**6-13.3(5).GR6**

**Precast Concrete Facing Panel and Concrete Block Erection**

**6-13.3(5).INST1.GR6**

(Section 6-13.3(5) is supplemented with the following)

Must use once preceding any of the following:

**6-13.3(5).OPT2.GB6**

(Specific Erection Requirements for Precast Concrete Block Faced Structural Earth Walls) (April 2, 2012)

Use in projects with structural earth walls where concrete block faced walls are an acceptable alternative. Include with **6-13.2.OPT3.GB6 6-13.3.OPT3.GB6, and 6-13.3(2).OPT1.FB6.**

**6-13.3(7).GR6**

**Backfill**

**6-13.3(7).INST1.GR6**

(Section 6-13.3(7) is supplemented with the following)

Must use once preceding any of the following:

**6-13.3(7).OPT1.GB6**

(Specific Backfill Requirements for Precast Concrete Panel Faced Structural Earth Walls) (August 3, 2015)

Use in projects with structural earth walls only when the following conditions apply:

1. Both precast concrete panel faced structural earth walls AND precast concrete block faced structural earth walls are included in the project as acceptable alternatives.
2. Lock + Load retaining wall system shall be constructed in areas where the wall will be constructed above the water table.

Include with **6-13.2.OPT2.GB6, 6-13.2.OPT2(A).GB6, 6-13.3.OPT2.GB6, 6-13.3.OPT2(A).GB6, 6-**

**6-14.GR6**

**Geosynthetic Retaining Walls**

**6-14.2.GR6**

**Materials**

**6-14.2(9-33.2(2)).GR6**

(Geosynthetic Properties For Retaining Walls and Reinforced Slopes  
(Section 9-33.2(2) is supplemented with the following)  
Must use once preceding any of the following:

**6-14.2(9-33.2(2)).OPT1.FB6**

(Geosynthetic Properties For Temporary Geosynthetic Retaining Walls)  
(August 7, 2006)  
Use in projects with temporary geosynthetic retaining walls. The first fill-in identifies the wall location. The second fill-in specifies the reinforcement layer vertical spacing. The third fill-in specifies the dimension from the top of wall to the reinforcement layer. The fourth fill-in specifies the geosynthetic tensile strength.  
(4 fill-ins)

**6-15.GR6**

**Soil Nail Walls**

**6-15.2.GR6**

**Materials**

**6-15.2.INST1.GR6**

(Section 6-15.2 is supplemented with the following)  
Must use once preceding any of the following:

**6-15.2.OPT1.GB6**

(Permanent Soil Nail Materials and Components)  
(August 3, 2015)  
Use in projects with soil nail retaining walls. Include with **6-15.3(8)A.OPT1.FB6**.

**6-15.3.GR6**

**Construction Requirements**

**6-15.3(8).GR6**

**Soil Nail Testing And Acceptance**

**6-15.3(8)A.GR6**

**Verification Testing**

**6-15.3(8)A.INST1.GR6**

(Section 6-15.3(8)A is supplemented with the following)  
Must use once preceding any of the following:

**6-15.3(8)A.OPT1.FB6**

(Soil Nail Verification Test Locations)  
(April 5, 2004)  
Use in projects with soil nail retaining walls. The fill-ins specify the soil nail verification test locations and the number of successful tests required at each location. Include with **6-15.2.OPT1.GB6**.  
(3 fill-ins)

## **6-17.GR6**                      **Permanent Ground Anchors**

### **6-17.1.GR6**                      **Description**

**6-17.1.INST1.GR6**                      (Section 6-17.1 is supplemented with the following)  
Must use once preceding any of the following:

**6-17.1.OPT1.GB6**                      (Rock Bolts and Rock Dowels)  
(January 7, 2013)  
Use in projects with rock bolts and/or rock dowels. Include  
with **6-17.2.OPT2.GB6**, **6-17.3.OPT1.GB6**, **6-17.3(8).OPT1.GB6**, **6-17.4.OPT1.GB6** and **6-17.5.OPT1.GB6**.

### **6-17.2.GR6**                      **Materials**

**6-17.2.INST1.GR6**                      (Section 6-17.2 is supplemented with the following)  
Must use once preceding any of the following:

**6-17.2.OPT1.GB6**                      (Permanent Ground Anchor Materials and  
Components)  
(November 2, 2022)  
Use in projects with walls using permanent ground  
anchors.

**6-17.2.OPT2.GB6**                      (Rock Bolt and Rock Dowel Materials)  
(January 7, 2013)  
Use in projects with rock bolts and/or rock dowels. Include  
with **6-17.1.OPT1.GB6**, **6-17.3.OPT1.GB6**, **6-17.3(8).OPT1.GB6**, **6-17.4.OPT1.GB6** and **6-17.5.OPT1.GB6**.

### **6-17.3.GR6**                      **Construction Requirements**

**6-17.3.INST1.GR6**                      (Section 6-17.3 is supplemented with the following)  
Must use once preceding any of the following:

**6-17.3.OPT1.GB6**                      (Rock Bolt and Rock Dowel  
Construction Requirements)  
(September 8, 2020)  
Use in projects with rock bolts and/or rock dowels. Include  
with **6-17.1.OPT1.GB6**, **6-17.2.OPT2.GB6**, **6-17.3(8).OPT1.GB6**, **6-17.4.OPT1.GB6** and **6-17.5.OPT1.GB6**.

### **6-17.3(8).GR6**                      **Testing And Stressing**

**6-17.3(8).INST1.GR6**                      (Section 6-17.3(8) is supplemented with the  
following)  
Must use once preceding any of the following:

**6-17.3(8).OPT1.GB6**                      Rock Bolt and Rock Dowel Testing

(January 7, 2013)  
Use in projects with rock bolts and/or rock dowels.  
Include with **6-17.1.OPT1.GB6**, **6-17.2.OPT2.GB6**, **6-17.3.OPT1.GB6**, **6-17.4.OPT1.GB6** and **6-17.5.OPT1.GB6**.

#### **6-17.3(8)A.GR6**

#### **Verification Testing**

**6-17.3(8)A.INST1.GR6** (Section 6-17.3(8)A is supplemented with the following)  
Must use once preceding any of the following:

**6-17.3(8)A.OPT1.GB6** (August 3, 2015)  
Use in projects with permanent ground anchors where the soil conditions require a verification testing program for the permanent ground anchors as recommended by the State Geotechnical Office. Include with **6-17.3(8)B.OPT1.GB6** and **6-17.3(8)C.OPT1.GB6**.

#### **6-17.3(8)B.GR6**

#### **Performance Testing**

**6-17.3(8)B.INST1.GR6** (The performance test schedule following the second paragraph of Section 6-17.3(8)B is revised to read)  
Must use once preceding any of the following:

**6-17.3(8)B.OPT1.GB6** (January 3, 2011)  
Use in projects with permanent ground anchors where the soil conditions require a verification testing program for the permanent ground anchors, as recommended by the State Geotechnical Office. Include with **6-17.3(8)A.OPT1.GB6** and **6-17.3(8)C.OPT1.GB6**.

#### **6-17.3(8)C.GR6**

#### **Proof Testing**

**6-17.3(8)C.INST1.GR6** (The proof test schedule following the first paragraph of Section 6-17.3(8)C is revised to read)  
Must use once preceding any of the following:

**6-17.3(8)C.OPT1.GB6** (January 3, 2011)  
Use in projects with permanent ground anchors where the soil conditions require a verification testing program for the permanent ground anchors, as recommended by the State Geotechnical Office. Include with **6-17.3(8)A.OPT1.GB6** and **6-17.3(8)B.OPT1.GB6**.

#### **6-17.4.GR6**

#### **Measurement**

**6-17.4.INST1.GR6** (Section 6-17.4 is supplemented with the following)  
Must use once preceding any of the following:

[6-17.4.OPT1.GB6](#)

(Rock Bolts and Rock Dowels)  
(January 4, 2010)

Use in projects with rock bolts and/or rock dowels. Include with **6-17.1.OPT1.GB6**, **6-17.2.OPT2.GB6**, **6-17.3.OPT1.GB6**, **6-17.3(8).OPT1.GB6**, and **6-17.5.OPT1.GB6**.

[6-17.5.GR6](#)

**Payment**

[6-17.5.INST1.GR6](#)

(Section 6-17.5 is supplemented with the following)  
Must use once preceding any of the following:

[6-17.5.OPT1.GB6](#)

(Rock Bolts and Rock Dowels)  
(January 4, 2010)

Use in projects with rock bolts and/or rock dowels. Include with **6-17.1.OPT1.GB6**, **6-17.2.OPT2.GB6**, **6-17.3.OPT1.GB6**, **6-17.3(8).OPT1.GB6**, and **6-17.4.OPT1.GB6**.

[6-18.GR6](#)

**Shotcrete Facing**

[6-18.2.GR6](#)

**Materials**

[6-18.2.INST1.GR6](#)

(Section 6-18.2 is supplemented with the following)  
Must use once preceding any of the following:

[6-18.2.OPT2.GB6](#)

(Coloration for Shotcrete Facing Finishing  
Alternative C)  
(August 3, 2015)

Use in projects with shotcrete facing where tinting of the finish coating of shotcrete is required.  
Must also use with **6-18.SA1.2025.GR6**.

[6-18.2.OPT3.GB6](#)

(Fiber Reinforcement for Shotcrete Facing)  
(August 3, 2015)

Use in projects with shotcrete facing where fiber reinforcement in the shotcrete is specified.  
Must also use with **6-18.SA1.2025.GR6**.

[6-19.GR6](#)

**Shafts**

[6-19.2.GR6](#)

**Materials**

[6-19.2\(9-36.2\(2\)\).GR6](#)

**Synthetic Slurry**

(Section 9-36.2(2) is supplemented with the following)  
Must use once preceding any of the following:

[6-19.2\(9-36.2\(2\)\).OPT1.GB6](#)

(Fresh Water for Synthetic Slurry)  
(January 2, 2012)

Use in projects with shafts constructed in salt water when the geotechnical report specifies that the use of fresh water for synthetic slurry is

feasible and when the Contracting Agency restricts the water for synthetic slurry to fresh water only. Include with **6-19.4.OPT3.GB6** and **6-19.5.OPT2.GB6**.

**6-19.2(9-36.4).GR6**

(Access Tubes and Caps)  
(The first paragraph of Section 9-36.4 is revised to read)  
Must use once preceding any of the following:

**6-19.2(9-36.4).OPT1.GR6**

(Shaft Related Materials)

(October 3, 2022)

Use in projects that contain shaft construction and crosshole sonic log testing is required.

**6-19.3.GR6**

**Construction Requirements**

**6-19.3(3).GR6**

**Shaft Excavation**

**6-19.3(3).INST1.GR6**

(Section 6-19.3(3) is supplemented with the following)  
Must use once preceding any of the following:

**6-19.3(3).OPT1.GB6**

(Variations In Bearing Layer Elevations)

(January 2, 2012)

Use in projects where shaft embedment to a minimum penetration into a bearing layer is required, and where the bearing layer elevation cannot be accurately specified with certainty. Include with **6-19.3(5).OPT1.GB6**.

**6-19.3(3)B.GR6**

**Temporary and Permanent Shaft Casing**

**6-19.3(3)B.INST1.GR6**

(Section 6-19.3(3)B is supplemented with the following)

Must use once preceding any of the following:

**6-19.3(3)B.OPT2.GB6**

(Rotating/Oscillating Method Required)

(January 2, 2012)

Use in projects where the geotechnical report for the project recommends, and the ADSC/WSDOT Shaft Task Force concurs, that site conditions dictate the use of the rotating/oscillating method for shaft excavation.

**6-19.3(3)B4.GR6**

**Temporary Telescoping Shaft Casing**

**6-19.3(3)B4.INST1.GR6**

(The second paragraph of Section 6-19.3(3)B4 is revised to read as follows)

Must use once preceding any of the following:

**6-19.3(3)B4.OPT1.GB6**

(Temp. Telescoping Casing Not Allowed At End Piers)

(January 2, 2012)

1 Use in projects where design conditions exist  
2 where the option of temporary telescoping casing  
3 for shafts at bridge end piers is not appropriate  
4 for the overall design behavior of the overall  
5 bridge.  
6

7 **6-19.3(3)I.GR6**

8 **Required Use of Slurry in Shaft Excavation**

9 **6-19.3(3)I.INST1.GR6**

10 (Section 6-19.3(3)I is supplemented with the following)  
11 Must use once preceding any of the following:

12 **6-19.3(3)I.OPT1.GB6**

13 (Exception For Casing Sealed Against  
14 Influx Of Water Into Excavation)  
15 (August 3, 2015)

16 Use in projects where the geotechnical  
17 conditions, as documented in the geotechnical  
18 report for the project, allow the possibility of  
19 performing shaft excavation in a cased hole  
20 beneath the water table level without the need for  
21 slurry to ensure the stability of the bottom of the  
22 excavation.

23 **6-19.3(4).GR6**

24 **Slurry Installation Requirements**

25 **6-19.3(4)A.GR6**

26 **Slurry Technical Assistance**

27 **6-19.3(4)A.INST1.GR6**

28 (Section 6-19.3(4)A is supplemented  
29 with the following)  
30 Must use once preceding any of the following:

31 **6-19.3(4)A.OPT1.FB6**

32 (Slurry Manufacturer's Representative's  
33 Presence Required At Specific Shaft Sites)  
34 (January 2, 2012)

35 Use in projects where the geotechnical  
36 conditions vary enough from one shaft site to  
37 another to affect how the slurry is used at each  
38 shaft site. The fill-in identifies the specific shaft  
39 locations where the presence of the slurry  
40 manufacturer's representative is required.  
41 (1 fill-in)

42 **6-19.3(5).GR6**

43 **Assembly and Placement of Reinforcing Steel**

44 **6-19.3(5).INST1.GR6**

45 (Section 6-19.3(5) is supplemented with the following)  
46 Must use once preceding any of the following:

47 **6-19.3(5).OPT1.GB6**

48 (Variations In Bearing Layer Elevations)  
49 (August 1, 2016)

50 Use in projects where shaft embedment to a  
51 minimum penetration into a bearing layer is  
52 required, and where the bearing layer elevation  
53 cannot be accurately specified with certainty.  
Include with **6-19.3(3).OPT1.GB6**.

**6-19.3(6).GR6**

**Contractor Furnished Accessories for Nondestructive QA Testing**

**6-19.3(6)E.GR6**

**Thermal Wire and Thermal Access Points (TAPs)**

**6-19.3(6)E.INST1.GR6** (Section 6-19.3(6)E is supplemented with the following)

Must use once preceding any of the following:

**6-19.3(6)E.OPT1.GB6**

(Thermal Wire and Associated Couplers)  
(January 2, 2018)

Use in projects that include shaft construction requiring nondestructive testing. This includes all bridge foundation shafts, but may or may not include other shafts such as sign bridges, cantilever sign structures, signal standards, etc.

**6-19.3(7).GR6**

**Placing Concrete**

**6-19.3(7)D.GR6**

**Requirements for Placing Concrete Underwater**

**6-19.3(7)D.INST1.GR6** (Section 6-19.3(7)D is supplemented with the following)

Must use once preceding any of the following:

**6-19.3(7)D.OPT1.GB6**

(Tremie Allowed As An Alternative To Concrete Pump)  
(January 2, 2012)

Use in projects where the construction site is at a remote location where it may be difficult to make arrangements to have a concrete pump at the site.

**6-19.4.GR6**

**Measurement**

**6-19.4.INST2.GR6**

(Section 6-19.4 is supplemented with the following)  
Must use once preceding any of the following:

**6-19.4.OPT3.GB6**

(Fresh Water For Synthetic Slurry)  
(January 2, 2012)

Use in projects with shafts constructed in salt water when the geotechnical report specifies that the use of fresh water for synthetic slurry is feasible and when the Contracting Agency restricts the water for synthetic slurry to fresh water only. Include with **6-19.2(9-36.2(2)).OPT1.GB6** and **6-19.5.OPT2.GB6**.

**6-19.5.GR6**

**Payment**

**6-19.5.INST1.GR6**

(Section 6-19.5 is supplemented with the following)  
Must use once preceding any of the following:

[6-19.5.OPT2.GB6](#)

(Fresh Water for Synthetic Slurry)

(January 2, 2012)

Use in projects with shafts constructed in salt water when the geotechnical report specifies that the use of fresh water for synthetic slurry is feasible and when the Contracting Agency restricts the water for synthetic slurry to fresh water only. Include with **6-19.2(9-36.2(2)).OPT1.GB6** and **6-19.4.OPT3.GB6**.

[6-20.GR6](#)

**Buried Structures**

[6-20.1.GR6](#)

**Description**

[6-20.1\(1\).GR6](#)

**Definitions**

[6-20.1\(1\).INST1.GR6](#)

(The list of types of buried structures in Section 6-20.1(1) is supplemented with the following:)

Must use once preceding any of the following:

[6-20.1\(1\).OPT1.GB6](#)

(March 20, 2025)

Use in all projects requiring the use of a Contractor-designed buried structure. Must be included with **6-20.2.OPT1.GB6**, **6-20.3.OPT1.GB6**, and **6-20.5.OPT1.GB6**.

[6-20.2.GR6](#)

**Materials**

[6-20.2.INST1.GR6](#)

(Section 6-20.2 is supplemented with the following)

Must use once preceding any of the following:

[6-20.2.OPT1.GB6](#)

(January 10, 2022)

Use in all projects requiring the use of a Contractor-designed buried structure. Must be included with **6-20.1(1).OPT1.GB6**, **6-20.3.OPT1.GB6**, and **6-20.5.OPT1.GB6**.

[6-20.3.GR6](#)

**Construction Requirements**

[6-20.3.INST1.GR6](#)

(Section 6-20.3 is supplemented with the following)

Must use once preceding any of the following:

[6-20.3.OPT1.GB6](#)

(January 10, 2022)

Use in all projects requiring the use of a Contractor-designed buried structure. Must be included with **6-20.1(1).OPT1.GB6**, **6-20.2.OPT1.GB6**, and **6-20.5.OPT1.GB6**.

[6-20.3\(1\).GR6](#)

**Design**

[6-20.5.GR6](#)

**Payment**

[6-20.5.INST1.GR6](#)

(Section 6-20.5 is supplemented with the following)

Must use once preceding any of the following:

1  
2  
3  
4  
5  
6  
7  
8  
9  
10

[6-20.5.OPT1.GB6](#)

(January 10, 2022)  
Use in all projects requiring the use of a Contractor-  
designed buried structure. Must be included with **6-  
20.1(1).OPT1.GB6**, **6-20.2.OPT1.GB6**, and **6-  
20.3.OPT1.GB6**.

[6-SA1.FR6](#)

**Polyester Concrete Overlay**  
(September 3, 2024)  
Use in projects with polyester concrete bridge deck overlays.